

THE TOWN OF MOUNT AIRY, MARYLAND

**TOWN COUNCIL
RESOLUTION NO. 2026-2**

**FOR THE PURPOSE OF ESTABLISHING
THE TOWN'S AVAILABLE WATER AND SEWER
CAPACITY YIELD FROM 2026 THROUGH 2027
PURSUANT TO THE TOWN CODE,
SECTION 109-19.2A and B AND
SECTION 91-6B**

Pursuant to the Town Code, Section 109-19.2A and B and Section 91-6B, be it RESOLVED, by the Town Council:

- (1) That the Town will for the period from 2026 through 2027 the Town will have available water capacity of 63,815 gpd based on the APFO Water and Sewer System calculations. This 63,815 gpd shall be the Available Water Capacity Yield from 2026 through 2027 which shall be available to be allocated in that time frame in accordance with the Town's Water and Sewer Allocation Ordinance to "New Demand" as defined therein.
- (2) That the Town will for the period from 2026 through 2027 have available sewer capacity of 306,453 gpd based on the APFO Water and Sewer System calculations. This 306,453 shall be the Available Sewer Capacity Yield from 2026 through 2027 which shall be available to be allocated in that time frame in accordance with the Town's Water and Sewer Allocation Ordinance to "New Demand" as defined therein.
- (3) That in the first quarter of 2026 the Town anticipates receiving an increase in appropriation from 79,000 gpd to 113,000 gpd from Maryland Department of the Environment (MDE) for permit FR2001G022(03), or well number 9. Once received this 34,000 gpd will add 29,920 gpd (or 88%) to the Available Water Capacity Yield bringing the total from 63,815 gpd to 93,735 gpd.

ADOPTED:

This 2nd day of February, 2026 by a vote of ___ in favor and ___ opposed.

ATTEST:

Jason P. Evans, Secretary

Tim J. Washabaugh, President of the Council

Approved this 2nd day of February, 2026.

ATTEST:

Jason P. Evans , Secretary

Larry G. Hushour, Mayor

Reviewed and approved as to legal sufficiency.
This 2nd day of February, 2026.

Thomas V. McCarron, Town Attorney