



Water Testing Labs of Maryland

1000 Butterworth Ct.
Thompson Creek Business Park
Stevensville, MD 21666
(410) 643-7711
sales@wtlmd.com

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 2/23/23
PWSID #: MD0060007

Sample ID: KR-23-0121
Sample Source: Well #1 - Sample Tap
Date/Time Collected: 2/6/23 1400
Date/Time Received by lab: 2/6/23 1555
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

| Parameter | Result | Units | Report Limit | Analytical Method | Date Analyzed |
|--|--------|-------|--------------|-------------------|---------------|
| Perfluorooctanesulfonic acid (PFOS) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroundecanoic acid (PFUnA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanoic acid (PFHxA) | 3.0 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorododecanoic acid (PFDoA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorooctanoic acid (PFOA) | 4.1 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorodecanoic acid (PFDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanesulfonic acid (PFHxS) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorobutanesulfonic acid (PFBS) | 5.2 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroheptanoic acid (PFHpA) | 1.9 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorononanoic acid (PFNA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotetradecanoic acid (PFTeDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotridecanoic acid (PFTrDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Hexafluoropropylene Oxide DimerAcid (HFPO-DA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,

T. Davis

T. Davis, Customer Service Representative



Water Testing Labs of Maryland

1000 Butterworth Ct.
Thompson Creek Business Park
Stevensville, MD 21666
(410) 643-7711
sales@wtlmd.com

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 2/23/23
PWSID #: MD0060007

Sample ID: KR-23-0122
Sample Source: Well #2 - Sample Tap
Date/Time Collected: 2/6/23 1354
Date/Time Received by lab: 2/6/23 1555
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

| Parameter | Result | Units | Report Limit | Analytical Method | Date Analyzed |
|--|--------|-------|--------------|-------------------|---------------|
| Perfluorooctanesulfonic acid (PFOS) | 6.5 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroundecanoic acid (PFUnA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanoic acid (PFHxA) | 2.1 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorododecanoic acid (PFDoA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorooctanoic acid (PFOA) | 2.5 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorodecanoic acid (PFDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanesulfonic acid (PFHxS) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorobutanesulfonic acid (PFBS) | 3.9 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroheptanoic acid (PFHpA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorononanoic acid (PFNA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotetradecanoic acid (PFTeDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotridecanoic acid (PFTrDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,

T. Davis

T. Davis, Customer Service Representative



Water Testing Labs of Maryland

1000 Butterworth Ct.
Thompson Creek Business Park
Stevensville, MD 21666
(410) 643-7711
sales@wtlmd.com

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 2/23/23
PWSID #: MD0060007

Sample ID: KR-23-0123
Sample Source: Well #3 - Sample Tap
Date/Time Collected: 2/6/23 1343
Date/Time Received by lab: 2/6/23 1555
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

| Parameter | Result | Units | Report Limit | Analytical Method | Date Analyzed |
|--|--------|-------|--------------|-------------------|---------------|
| Perfluorooctanesulfonic acid (PFOS) | 2.1 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroundecanoic acid (PFUnA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanoic acid (PFHxA) | 2.6 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorododecanoic acid (PFDoA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorooctanoic acid (PFOA) | 4.1 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorodecanoic acid (PFDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanesulfonic acid (PFHxS) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorobutanesulfonic acid (PFBS) | 4.1 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroheptanoic acid (PFHpA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorononanoic acid (PFNA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotetradecanoic acid (PFTeDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotridecanoic acid (PFTrDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Hexafluoropropylene Oxide DimerAcid (HFPO-DA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,

T. Davis

T. Davis, Customer Service Representative



Water Testing Labs of Maryland

1000 Butterworth Ct.
Thompson Creek Business Park
Stevensville, MD 21666
(410) 643-7711
sales@wtlmd.com

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 2/23/23
PWSID #: MD0060007

Sample ID: KR-23-0124
Sample Source: Well #4 - Sample Tap
Date/Time Collected: 2/6/23 1342
Date/Time Received by lab: 2/6/23 1555
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

| Parameter | Result | Units | Report Limit | Analytical Method | Date Analyzed |
|--|--------|-------|--------------|-------------------|---------------|
| Perfluorooctanesulfonic acid (PFOS) | 4.8 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroundecanoic acid (PFUnA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanoic acid (PFHxA) | 4.4 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorododecanoic acid (PFDoA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorooctanoic acid (PFOA) | 4.6 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorodecanoic acid (PFDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanesulfonic acid (PFHxS) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorobutanesulfonic acid (PFBS) | 8.0 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroheptanoic acid (PFHpA) | 2.5 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorononanoic acid (PFNA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotetradecanoic acid (PFTeDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotridecanoic acid (PFTrDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Hexafluoropropylene Oxide DimerAcid (HFPO-DA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,

T. Davis

T. Davis, Customer Service Representative



Water Testing Labs of Maryland

1000 Butterworth Ct.
Thompson Creek Business Park
Stevensville, MD 21666
(410) 643-7711
sales@wtlmd.com

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 2/23/23
PWSID #: MD0060007

Sample ID: KR-23-0125
Sample Source: Well #5 - Sample Tap
Date/Time Collected: 2/6/23 1307
Date/Time Received by lab: 2/6/23 1555
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

| Parameter | Result | Units | Report Limit | Analytical Method | Date Analyzed |
|--|--------|-------|--------------|-------------------|---------------|
| Perfluorooctanesulfonic acid (PFOS) | 9.5 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroundecanoic acid (PFUnA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanoic acid (PFHxA) | 4.6 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorododecanoic acid (PFDoA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorooctanoic acid (PFOA) | 7.7 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorodecanoic acid (PFDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanesulfonic acid (PFHxS) | 2.4 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorobutanesulfonic acid (PFBS) | 6.6 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroheptanoic acid (PFHpA) | 3.1 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorononanoic acid (PFNA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotetradecanoic acid (PFTeDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotridecanoic acid (PFTrDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,

T. Davis

T. Davis, Customer Service Representative



Water Testing Labs of Maryland

1000 Butterworth Ct.
Thompson Creek Business Park
Stevensville, MD 21666
(410) 643-7711
sales@wtlmd.com

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 2/23/23
PWSID #: MD0060007

Sample ID: KR-23-0126
Sample Source: Well #6 - Sample Tap
Date/Time Collected: 2/6/23 1308
Date/Time Received by lab: 2/6/23 1555
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

| Parameter | Result | Units | Report Limit | Analytical Method | Date Analyzed |
|--|--------|-------|--------------|-------------------|---------------|
| Perfluorooctanesulfonic acid (PFOS) | 5.6 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroundecanoic acid (PFUnA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanoic acid (PFHxA) | 4.6 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorododecanoic acid (PFDoA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorooctanoic acid (PFOA) | 5.2 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorodecanoic acid (PFDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanesulfonic acid (PFHxS) | 2.6 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorobutanesulfonic acid (PFBS) | 2.6 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroheptanoic acid (PFHpA) | 2.6 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorononanoic acid (PFNA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotetradecanoic acid (PFTeDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotridecanoic acid (PFTrDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,

T. Davis

T. Davis, Customer Service Representative



Water Testing Labs of Maryland

1000 Butterworth Ct.
Thompson Creek Business Park
Stevensville, MD 21666
(410) 643-7711
sales@wtlmd.com

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 2/23/23
PWSID #: MD0060007

Sample ID: KR-23-0127
Sample Source: Well #7 - Sample Tap
Date/Time Collected: 2/6/23 1430
Date/Time Received by lab: 2/6/23 1555
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

| Parameter | Result | Units | Report Limit | Analytical Method | Date Analyzed |
|--|--------|-------|--------------|-------------------|---------------|
| Perfluorooctanesulfonic acid (PFOS) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroundecanoic acid (PFUnA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanoic acid (PFHxA) | 3.3 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorododecanoic acid (PFDoA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorooctanoic acid (PFOA) | 2.9 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorodecanoic acid (PFDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanesulfonic acid (PFHxS) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorobutanesulfonic acid (PFBS) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroheptanoic acid (PFHpA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorononanoic acid (PFNA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotetradecanoic acid (PFTeDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotridecanoic acid (PFTrDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,

T. Davis

T. Davis, Customer Service Representative



Water Testing Labs of Maryland

1000 Butterworth Ct.
Thompson Creek Business Park
Stevensville, MD 21666
(410) 643-7711
sales@wtlmd.com

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 2/23/23
PWSID #: MD0060007

Sample ID: KR-23-0128
Sample Source: Well #8 - Sample Tap
Date/Time Collected: 2/6/23 1326
Date/Time Received by lab: 2/6/23 1555
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

| Parameter | Result | Units | Report Limit | Analytical Method | Date Analyzed |
|--|--------|-------|--------------|-------------------|---------------|
| Perfluorooctanesulfonic acid (PFOS) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroundecanoic acid (PFUnA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanoic acid (PFHxA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorododecanoic acid (PFDoA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorooctanoic acid (PFOA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorodecanoic acid (PFDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanesulfonic acid (PFHxS) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorobutanesulfonic acid (PFBS) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroheptanoic acid (PFHpA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorononanoic acid (PFNA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotetradecanoic acid (PFTeDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotridecanoic acid (PFTrDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,

T. Davis

T. Davis, Customer Service Representative



Water Testing Labs of Maryland

1000 Butterworth Ct.
Thompson Creek Business Park
Stevensville, MD 21666
(410) 643-7711
sales@wtlmd.com

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 2/23/23
PWSID #: MD0060007

Sample ID: KR-23-0129
Sample Source: Well #9 - Sample Tap
Date/Time Collected: 2/6/23 1413
Date/Time Received by lab: 2/6/23 1555
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

| Parameter | Result | Units | Report Limit | Analytical Method | Date Analyzed |
|--|--------|-------|--------------|-------------------|---------------|
| Perfluorooctanesulfonic acid (PFOS) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroundecanoic acid (PFUnA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanoic acid (PFHxA) | 4.1 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorododecanoic acid (PFDoA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorooctanoic acid (PFOA) | 4.4 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorodecanoic acid (PFDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanesulfonic acid (PFHxS) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorobutanesulfonic acid (PFBS) | 2.3 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroheptanoic acid (PFHpA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorononanoic acid (PFNA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotetradecanoic acid (PFTeDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotridecanoic acid (PFTrDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,

T. Davis

T. Davis, Customer Service Representative

WTL



Water Testing Labs of Maryland

1000 Butterworth Ct.
Thompson Creek Business Park
Stevensville, MD 21666
(410) 643-7711
sales@wtlmd.com

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 2/23/23
PWSID #: MD0060007

Sample ID: KR-23-0130
Sample Source: Well #10 - Sample Tap
Date/Time Collected: 2/6/23 1327
Date/Time Received by lab: 2/6/23 1555
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

| Parameter | Result | Units | Report Limit | Analytical Method | Date Analyzed |
|--|--------|-------|--------------|-------------------|---------------|
| Perfluorooctanesulfonic acid (PFOS) | ND | ppt | 2.0 | EPA 537.1 | 2/21/23 |
| Perfluoroundecanoic acid (PFUnA) | ND | ppt | 2.0 | EPA 537.1 | 2/21/23 |
| Perfluorohexanoic acid (PFHxA) | ND | ppt | 2.0 | EPA 537.1 | 2/21/23 |
| Perfluorododecanoic acid (PFDoA) | ND | ppt | 2.0 | EPA 537.1 | 2/21/23 |
| Perfluorooctanoic acid (PFOA) | ND | ppt | 2.0 | EPA 537.1 | 2/21/23 |
| Perfluorodecanoic acid (PFDA) | ND | ppt | 2.0 | EPA 537.1 | 2/21/23 |
| Perfluorohexanesulfonic acid (PFHxS) | ND | ppt | 2.0 | EPA 537.1 | 2/21/23 |
| Perfluorobutanesulfonic acid (PFBS) | ND | ppt | 2.0 | EPA 537.1 | 2/21/23 |
| Perfluoroheptanoic acid (PFHpA) | ND | ppt | 2.0 | EPA 537.1 | 2/21/23 |
| Perfluorononanoic acid (PFNA) | ND | ppt | 2.0 | EPA 537.1 | 2/21/23 |
| Perfluorotetradecanoic acid (PFTeDA) | ND | ppt | 2.0 | EPA 537.1 | 2/21/23 |
| Perfluorotridecanoic acid (PFTrDA) | ND | ppt | 2.0 | EPA 537.1 | 2/21/23 |
| N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA) | ND | ppt | 2.0 | EPA 537.1 | 2/21/23 |
| N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA) | ND | ppt | 2.0 | EPA 537.1 | 2/21/23 |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) | ND | ppt | 2.0 | EPA 537.1 | 2/21/23 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid | ND | ppt | 2.0 | EPA 537.1 | 2/21/23 |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid | ND | ppt | 2.0 | EPA 537.1 | 2/21/23 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | ND | ppt | 2.0 | EPA 537.1 | 2/21/23 |

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,

T. Davis

T. Davis, Customer Service Representative



Water Testing Labs of Maryland

1000 Butterworth Ct.
Thompson Creek Business Park
Stevensville, MD 21666
(410) 643-7711
sales@wtlmd.com

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 2/23/23
PWSID #: MD0060007

Sample ID: KR-23-0131
Sample Source: Well #11 - Sample Tap
Date/Time Collected: 2/6/23 1445
Date/Time Received by lab: 2/6/23 1555
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

| Parameter | Result | Units | Report Limit | Analytical Method | Date Analyzed |
|--|--------|-------|--------------|-------------------|---------------|
| Perfluorooctanesulfonic acid (PFOS) | 3.4 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroundecanoic acid (PFUnA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanoic acid (PFHxA) | 1.9 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorododecanoic acid (PFDoA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorooctanoic acid (PFOA) | 3.0 | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorodecanoic acid (PFDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorohexanesulfonic acid (PFHxS) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorobutanesulfonic acid (PFBS) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluoroheptanoic acid (PFHpA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorononanoic acid (PFNA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotetradecanoic acid (PFTeDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Perfluorotridecanoic acid (PFTrDA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |
| 4,8-Dioxa-3H-perfluorononanoic acid (ADONA) | ND | ppt | 1.9 | EPA 537.1 | 2/21/23 |

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,


T. Davis

T. Davis, Customer Service Representative

Daily POE (Point of Entry)-Finished Water-Chain of Custody (COMMUNITY & NON-COMMUNITY SYSTEMS ONLY)

Sampler: Kevin Ramsey ID#: 2084KR Collection Date: 2/6/23

| ID # | PWSID | System Name | Plant ID | Plant Name/Site Address | POE Location | Time Collected | Lab Use Only | | |
|------------|-----------|------------------|----------|-------------------------|--------------|----------------|--------------|-----------------|--------------------------|
| | | | | | | | pH | Cl ₂ | D/T/A Preserved? |
| KR-23-0121 | MD0060007 | Town of Mt. Airy | ---- | Well #1 | Sample tap | 1400 | | | <input type="checkbox"/> |
| KR-23-0122 | MD0060007 | Town of Mt. Airy | ---- | Well #2 | Sample tap | 1354 | | | <input type="checkbox"/> |
| KR-23-0123 | MD0060007 | Town of Mt. Airy | ---- | Well #3 | Sample tap | 1343 | | | <input type="checkbox"/> |
| KR-23-0124 | MD0060007 | Town of Mt. Airy | ---- | Well #4 | Sample tap | 1342 | | | <input type="checkbox"/> |
| KR-23-0125 | MD0060007 | Town of Mt. Airy | ---- | Well #5 | Sample tap | 1307 | | | <input type="checkbox"/> |
| KR-23-0126 | MD0060007 | Town of Mt. Airy | ---- | Well #6 | Sample tap | 1308 | | | <input type="checkbox"/> |
| KR-23-0127 | MD0060007 | Town of Mt. Airy | ---- | Well #7 | Sample tap | 1430 | | | <input type="checkbox"/> |
| KR-23-0128 | MD0060007 | Town of Mt. Airy | ---- | Well #8 | Sample tap | 1326 | | | <input type="checkbox"/> |
| KR-23-0129 | MD0060007 | Town of Mt. Airy | ---- | Well #9 | Sample tap | 1413 | | | <input type="checkbox"/> |

| | | | |
|--|---|---|------------|
| RELINQUISHED BY:  | DATE/TIME: 2/6/23 1555 | RECEIVED BY: | DATE/TIME: |
| RELINQUISHED BY: | DATE/TIME: | RECEIVED BY: | DATE/TIME: |
| RECEIVED BY LAB: Meghan Clare | DATE/TIME: 2/6/2023 1555 | Preservatives: 1 - 4° 2 - H ₂ SO ₄ , 4° 3 - HNO ₃ , 4° 4 - HCl, 4° | |
| Labeled Preserved <input checked="" type="checkbox"/> | Ice: <input checked="" type="radio"/> Yes or No | Temperature: 3.9°C | Comments: |



Daily POE (Point of Entry)-Finished Water-Chain of Custody (COMMUNITY & NON-COMMUNITY SYSTEMS ONLY)

Sampler: Kevin Ramsey

ID#: 2084KR

Collection Date: 2/6/23

| ID # | PWSID | System Name | Plant ID | Plant Name/Site Address | POE Location | Time Collected | Lab Use Only | | |
|------------|-----------|------------------|----------|-------------------------|--------------|----------------|--------------|-----------------|------------------|
| | | | | | | | pH | Cl ₂ | D/T/A Preserved? |
| KR-23-0130 | MD0060007 | Town of Mt. Airy | ---- | Well #10 | Sample tap | 1327 | | | |
| KR-23-0131 | MD0060007 | Town of Mt. Airy | ---- | Well #11 | Sample tap | 1445 | | | |
| KR-23-0132 | | | | | | | | | |
| KR-23-0133 | | | | | | | | | |
| KR-23-0134 | | | | | | | | | |
| KR-23-0135 | | | | | | | | | |
| KR-23-0136 | | | | | | | | | |
| KR-23-0137 | | | | | | | | | |
| KR-23-0138 | | | | | | | | | |
| KR-23-0139 | | | | | | | | | |

| | | | |
|---|---|---|------------|
| RELINQUISHED BY:  | DATE/TIME: 2/6/23 1555 | RECEIVED BY: | DATE/TIME: |
| RELINQUISHED BY: | DATE/TIME: | RECEIVED BY: | DATE/TIME: |
| RECEIVED BY LAB:  | DATE/TIME: 2/6/2023 1555 | Preservatives: 1 - 4° 2 - H ₂ SO ₄ , 4° 3 - HNO ₃ , 4° 4 - HCl, 4° | |
| <input checked="" type="checkbox"/> Labeled Preserved | Ice: <input checked="" type="radio"/> Yes or No | Temperature: 3.9°C | Comments: |