

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 8/25/23
PWSID #: MD0060007

Sample ID: KR-23-0448
Sample Source: Well #1 - Sample Tap
Date/Time Collected: 8/9/23 1305
Date/Time Received by lab: 8/9/23 1520
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

Parameter	Result	Units	Report Limit	Analytical Method	Date Analyzed
Perfluorooctanesulfonic acid (PFOS)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluoroundecanoic acid (PFUnA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorohexanoic acid (PFHxA)	2.9	ppt	1.9	EPA 537.1	8/19/23
Perfluorododecanoic acid (PFDoA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorooctanoic acid (PFOA)	3.7	ppt	1.9	EPA 537.1	8/19/23
Perfluorodecanoic acid (PFDA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorohexanesulfonic acid (PFHxS)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorobutanesulfonic acid (PFBS)	5.4	ppt	1.9	EPA 537.1	8/19/23
Perfluoroheptanoic acid (PFHpA)	1.9	ppt	1.9	EPA 537.1	8/19/23
Perfluorononanoic acid (PFNA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorotetradecanoic acid (PFTeDA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorotridecanoic acid (PFTrDA)	ND	ppt	1.9	EPA 537.1	8/19/23
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND	ppt	1.9	EPA 537.1	8/19/23
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND	ppt	1.9	EPA 537.1	8/19/23
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	ND	ppt	1.9	EPA 537.1	8/19/23
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/19/23
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/19/23
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	ND	ppt	1.9	EPA 537.1	8/19/23

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,



K. Wentworth, Customer Service Representative

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 8/25/23
PWSID #: MD0060007

Sample ID: KR-23-0449
Sample Source: Well #2 - Sample Tap
Date/Time Collected: 8/9/23 1306
Date/Time Received by lab: 8/9/23 1520
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

Parameter	Result	Units	Report Limit	Analytical Method	Date Analyzed
Perfluorooctanesulfonic acid (PFOS)	5.2	ppt	1.9	EPA 537.1	8/19/23
Perfluoroundecanoic acid (PFUnA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorohexanoic acid (PFHxA)	3.9	ppt	1.9	EPA 537.1	8/19/23
Perfluorododecanoic acid (PFDoA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorooctanoic acid (PFOA)	4.7	ppt	1.9	EPA 537.1	8/19/23
Perfluorodecanoic acid (PFDA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorohexanesulfonic acid (PFHxS)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorobutanesulfonic acid (PFBS)	6.6	ppt	1.9	EPA 537.1	8/19/23
Perfluoroheptanoic acid (PFHpA)	2.4	ppt	1.9	EPA 537.1	8/19/23
Perfluorononanoic acid (PFNA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorotetradecanoic acid (PFTeDA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorotridecanoic acid (PFTrDA)	ND	ppt	1.9	EPA 537.1	8/19/23
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND	ppt	1.9	EPA 537.1	8/19/23
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND	ppt	1.9	EPA 537.1	8/19/23
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	ND	ppt	1.9	EPA 537.1	8/19/23
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/19/23
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/19/23
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	ND	ppt	1.9	EPA 537.1	8/19/23

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,



K. Wentworth, Customer Service Representative

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 8/25/23
PWSID #: MD0060007

Sample ID: KR-23-0447
Sample Source: Well #3 - Sample Tap
Date/Time Collected: 8/9/23 1304
Date/Time Received by lab: 8/9/23 1520
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

Parameter	Result	Units	Report Limit	Analytical Method	Date Analyzed
Perfluorooctanesulfonic acid (PFOS)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluoroundecanoic acid (PFUnA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorohexanoic acid (PFHxA)	2.9	ppt	1.9	EPA 537.1	8/19/23
Perfluorododecanoic acid (PFDoA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorooctanoic acid (PFOA)	4.0	ppt	1.9	EPA 537.1	8/19/23
Perfluorodecanoic acid (PFDA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorohexanesulfonic acid (PFHxS)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorobutanesulfonic acid (PFBS)	5.3	ppt	1.9	EPA 537.1	8/19/23
Perfluoroheptanoic acid (PFHpA)	2.1	ppt	1.9	EPA 537.1	8/19/23
Perfluorononanoic acid (PFNA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorotetradecanoic acid (PFTeDA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorotridecanoic acid (PFTrDA)	ND	ppt	1.9	EPA 537.1	8/19/23
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND	ppt	1.9	EPA 537.1	8/19/23
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND	ppt	1.9	EPA 537.1	8/19/23
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	ND	ppt	1.9	EPA 537.1	8/19/23
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/19/23
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/19/23
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	ND	ppt	1.9	EPA 537.1	8/19/23

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,



K. Wentworth, Customer Service Representative

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 8/25/23
PWSID #: MD0060007

Sample ID: KR-23-0450
Sample Source: Well #4 - Sample Tap
Date/Time Collected: 8/9/23 1308
Date/Time Received by lab: 8/9/23 1520
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

Parameter	Result	Units	Report Limit	Analytical Method	Date Analyzed
Perfluorooctanesulfonic acid (PFOS)	5.1	ppt	1.9	EPA 537.1	8/19/23
Perfluoroundecanoic acid (PFUnA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorohexanoic acid (PFHxA)	3.6	ppt	1.9	EPA 537.1	8/19/23
Perfluorododecanoic acid (PFDoA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorooctanoic acid (PFOA)	4.6	ppt	1.9	EPA 537.1	8/19/23
Perfluorodecanoic acid (PFDA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorohexanesulfonic acid (PFHxS)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorobutanesulfonic acid (PFBS)	6.8	ppt	1.9	EPA 537.1	8/19/23
Perfluoroheptanoic acid (PFHpA)	2.4	ppt	1.9	EPA 537.1	8/19/23
Perfluorononanoic acid (PFNA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorotetradecanoic acid (PFTeDA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorotridecanoic acid (PFTrDA)	ND	ppt	1.9	EPA 537.1	8/19/23
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND	ppt	1.9	EPA 537.1	8/19/23
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND	ppt	1.9	EPA 537.1	8/19/23
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	ND	ppt	1.9	EPA 537.1	8/19/23
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/19/23
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/19/23
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	ND	ppt	1.9	EPA 537.1	8/19/23

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,



K. Wentworth, Customer Service Representative

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 8/25/23
PWSID #: MD0060007

Sample ID: KR-23-0442
Sample Source: Well #5 - Sample Tap
Date/Time Collected: 8/9/23 1239
Date/Time Received by lab: 8/9/23 1520
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

Parameter	Result	Units	Report Limit	Analytical Method	Date Analyzed
Perfluorooctanesulfonic acid (PFOS)	9.0	ppt	1.9	EPA 537.1	8/19/23
Perfluoroundecanoic acid (PFUnA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorohexanoic acid (PFHxA)	4.8	ppt	1.9	EPA 537.1	8/19/23
Perfluorododecanoic acid (PFDoA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorooctanoic acid (PFOA)	7.2	ppt	1.9	EPA 537.1	8/19/23
Perfluorodecanoic acid (PFDA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorohexanesulfonic acid (PFHxS)	2.6	ppt	1.9	EPA 537.1	8/19/23
Perfluorobutanesulfonic acid (PFBS)	7.5	ppt	1.9	EPA 537.1	8/19/23
Perfluoroheptanoic acid (PFHpA)	3.5	ppt	1.9	EPA 537.1	8/19/23
Perfluorononanoic acid (PFNA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorotetradecanoic acid (PFTeDA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorotridecanoic acid (PFTrDA)	ND	ppt	1.9	EPA 537.1	8/19/23
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND	ppt	1.9	EPA 537.1	8/19/23
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND	ppt	1.9	EPA 537.1	8/19/23
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	ND	ppt	1.9	EPA 537.1	8/19/23
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/19/23
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/19/23
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	ND	ppt	1.9	EPA 537.1	8/19/23

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,



K. Wentworth, Customer Service Representative

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 8/25/23
PWSID #: MD0060007

Sample ID: KR-23-0441
Sample Source: Well #6 - Sample Tap
Date/Time Collected: 8/9/23 1238
Date/Time Received by lab: 8/9/23 1520
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

Parameter	Result	Units	Report Limit	Analytical Method	Date Analyzed
Perfluorooctanesulfonic acid (PFOS)	5.6	ppt	1.9	EPA 537.1	8/19/23
Perfluoroundecanoic acid (PFUnA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorohexanoic acid (PFHxA)	5.5	ppt	1.9	EPA 537.1	8/19/23
Perfluorododecanoic acid (PFDoA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorooctanoic acid (PFOA)	5.9	ppt	1.9	EPA 537.1	8/19/23
Perfluorodecanoic acid (PFDA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorohexanesulfonic acid (PFHxS)	2.7	ppt	1.9	EPA 537.1	8/19/23
Perfluorobutanesulfonic acid (PFBS)	2.8	ppt	1.9	EPA 537.1	8/19/23
Perfluoroheptanoic acid (PFHpA)	3.6	ppt	1.9	EPA 537.1	8/19/23
Perfluorononanoic acid (PFNA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorotetradecanoic acid (PFTeDA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorotridecanoic acid (PFTrDA)	ND	ppt	1.9	EPA 537.1	8/19/23
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND	ppt	1.9	EPA 537.1	8/19/23
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND	ppt	1.9	EPA 537.1	8/19/23
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	ND	ppt	1.9	EPA 537.1	8/19/23
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/19/23
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/19/23
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	ND	ppt	1.9	EPA 537.1	8/19/23

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,



K. Wentworth, Customer Service Representative

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 8/25/23
PWSID #: MD0060007

Sample ID: KR-23-0453
Sample Source: Well #7 - Sample Tap
Date/Time Collected: 8/9/23 1328
Date/Time Received by lab: 8/9/23 1520
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

Parameter	Result	Units	Report Limit	Analytical Method	Date Analyzed
Perfluorooctanesulfonic acid (PFOS)	6.8	ppt	1.9	EPA 537.1	8/18/23
Perfluoroundecanoic acid (PFUnA)	ND	ppt	1.9	EPA 537.1	8/18/23
Perfluorohexanoic acid (PFHxA)	33	ppt	1.9	EPA 537.1	8/18/23
Perfluorododecanoic acid (PFDoA)	ND	ppt	1.9	EPA 537.1	8/18/23
Perfluorooctanoic acid (PFOA)	28	ppt	1.9	EPA 537.1	8/18/23
Perfluorodecanoic acid (PFDA)	5.6	ppt	1.9	EPA 537.1	8/18/23
Perfluorohexanesulfonic acid (PFHxS)	ND	ppt	1.9	EPA 537.1	8/18/23
Perfluorobutanesulfonic acid (PFBS)	2.4	ppt	1.9	EPA 537.1	8/18/23
Perfluoroheptanoic acid (PFHpA)	12	ppt	1.9	EPA 537.1	8/18/23
Perfluorononanoic acid (PFNA)	3.1	ppt	1.9	EPA 537.1	8/18/23
Perfluorotetradecanoic acid (PFTeDA)	ND	ppt	1.9	EPA 537.1	8/18/23
Perfluorotridecanoic acid (PFTrDA)	ND	ppt	1.9	EPA 537.1	8/18/23
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND	ppt	1.9	EPA 537.1	8/18/23
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND	ppt	1.9	EPA 537.1	8/18/23
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	ND	ppt	1.9	EPA 537.1	8/18/23
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/18/23
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/18/23
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	ND	ppt	1.9	EPA 537.1	8/18/23

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,



K. Wentworth, Customer Service Representative

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 8/25/23
PWSID #: MD0060007

Sample ID: KR-23-0444
Sample Source: Well #8 - Sample Tap
Date/Time Collected: 8/9/23 1249
Date/Time Received by lab: 8/9/23 1520
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

Parameter	Result	Units	Report Limit	Analytical Method	Date Analyzed
Perfluorooctanesulfonic acid (PFOS)	ND	ppt	2.0	EPA 537.1	8/19/23
Perfluoroundecanoic acid (PFUnA)	ND	ppt	2.0	EPA 537.1	8/19/23
Perfluorohexanoic acid (PFHxA)	ND	ppt	2.0	EPA 537.1	8/19/23
Perfluorododecanoic acid (PFDoA)	ND	ppt	2.0	EPA 537.1	8/19/23
Perfluorooctanoic acid (PFOA)	ND	ppt	2.0	EPA 537.1	8/19/23
Perfluorodecanoic acid (PFDA)	ND	ppt	2.0	EPA 537.1	8/19/23
Perfluorohexanesulfonic acid (PFHxS)	ND	ppt	2.0	EPA 537.1	8/19/23
Perfluorobutanesulfonic acid (PFBS)	ND	ppt	2.0	EPA 537.1	8/19/23
Perfluoroheptanoic acid (PFHpA)	ND	ppt	2.0	EPA 537.1	8/19/23
Perfluorononanoic acid (PFNA)	ND	ppt	2.0	EPA 537.1	8/19/23
Perfluorotetradecanoic acid (PFTeDA)	ND	ppt	2.0	EPA 537.1	8/19/23
Perfluorotridecanoic acid (PFTrDA)	ND	ppt	2.0	EPA 537.1	8/19/23
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND	ppt	2.0	EPA 537.1	8/19/23
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND	ppt	2.0	EPA 537.1	8/19/23
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	ND	ppt	2.0	EPA 537.1	8/19/23
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	ND	ppt	2.0	EPA 537.1	8/19/23
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	ND	ppt	2.0	EPA 537.1	8/19/23
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	ND	ppt	2.0	EPA 537.1	8/19/23

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,



K. Wentworth, Customer Service Representative

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 8/25/23
PWSID #: MD0060007

Sample ID: KR-23-0452
Sample Source: Well #9 - Sample Tap
Date/Time Collected: 8/9/23 1317
Date/Time Received by lab: 8/9/23 1520
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

Parameter	Result	Units	Report Limit	Analytical Method	Date Analyzed
Perfluorooctanesulfonic acid (PFOS)	1.9	ppt	1.9	EPA 537.1	8/18/23
Perfluoroundecanoic acid (PFUnA)	ND	ppt	1.9	EPA 537.1	8/18/23
Perfluorohexanoic acid (PFHxA)	5.0	ppt	1.9	EPA 537.1	8/18/23
Perfluorododecanoic acid (PFDoA)	ND	ppt	1.9	EPA 537.1	8/18/23
Perfluorooctanoic acid (PFOA)	5.0	ppt	1.9	EPA 537.1	8/18/23
Perfluorodecanoic acid (PFDA)	ND	ppt	1.9	EPA 537.1	8/18/23
Perfluorohexanesulfonic acid (PFHxS)	ND	ppt	1.9	EPA 537.1	8/18/23
Perfluorobutanesulfonic acid (PFBS)	2.5	ppt	1.9	EPA 537.1	8/18/23
Perfluoroheptanoic acid (PFHpA)	ND	ppt	1.9	EPA 537.1	8/18/23
Perfluorononanoic acid (PFNA)	ND	ppt	1.9	EPA 537.1	8/18/23
Perfluorotetradecanoic acid (PFTeDA)	ND	ppt	1.9	EPA 537.1	8/18/23
Perfluorotridecanoic acid (PFTrDA)	ND	ppt	1.9	EPA 537.1	8/18/23
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND	ppt	1.9	EPA 537.1	8/18/23
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND	ppt	1.9	EPA 537.1	8/18/23
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	ND	ppt	1.9	EPA 537.1	8/18/23
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/18/23
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/18/23
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	ND	ppt	1.9	EPA 537.1	8/18/23

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,



K. Wentworth, Customer Service Representative

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 8/25/23
PWSID #: MD0060007

Sample ID: KR-23-0445
Sample Source: Well #10 - Sample Tap
Date/Time Collected: 8/9/23 1250
Date/Time Received by lab: 8/9/23 1520
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

Parameter	Result	Units	Report Limit	Analytical Method	Date Analyzed
Perfluorooctanesulfonic acid (PFOS)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluoroundecanoic acid (PFUnA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorohexanoic acid (PFHxA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorododecanoic acid (PFDoA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorooctanoic acid (PFOA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorodecanoic acid (PFDA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorohexanesulfonic acid (PFHxS)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorobutanesulfonic acid (PFBS)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluoroheptanoic acid (PFHpA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorononanoic acid (PFNA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorotetradecanoic acid (PFTeDA)	ND	ppt	1.9	EPA 537.1	8/19/23
Perfluorotridecanoic acid (PFTrDA)	ND	ppt	1.9	EPA 537.1	8/19/23
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND	ppt	1.9	EPA 537.1	8/19/23
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND	ppt	1.9	EPA 537.1	8/19/23
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	ND	ppt	1.9	EPA 537.1	8/19/23
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/19/23
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/19/23
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	ND	ppt	1.9	EPA 537.1	8/19/23

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,



K. Wentworth, Customer Service Representative

Town of Mt. Airy
PO Box 50
Mt. Airy MD 21771

Reporting Date: 8/25/23
PWSID #: MD0060007

Sample ID: KR-23-0454
Sample Source: Well #11 - Sample Tap
Date/Time Collected: 8/9/23 1336
Date/Time Received by lab: 8/9/23 1520
Sample Type: Drinking Water
Sampler/Company: K. Ramsey 2084KR, WTL of MD
Laboratory Certification: # 214

Analytical Results

Parameter	Result	Units	Report Limit	Analytical Method	Date Analyzed
Perfluorooctanesulfonic acid (PFOS)	5.9	ppt	1.9	EPA 537.1	8/18/23
Perfluoroundecanoic acid (PFUnA)	ND	ppt	1.9	EPA 537.1	8/18/23
Perfluorohexanoic acid (PFHxA)	3.1	ppt	1.9	EPA 537.1	8/18/23
Perfluorododecanoic acid (PFDoA)	ND	ppt	1.9	EPA 537.1	8/18/23
Perfluorooctanoic acid (PFOA)	5.5	ppt	1.9	EPA 537.1	8/18/23
Perfluorodecanoic acid (PFDA)	ND	ppt	1.9	EPA 537.1	8/18/23
Perfluorohexanesulfonic acid (PFHxS)	ND	ppt	1.9	EPA 537.1	8/18/23
Perfluorobutanesulfonic acid (PFBS)	2.4	ppt	1.9	EPA 537.1	8/18/23
Perfluoroheptanoic acid (PFHpA)	2.0	ppt	1.9	EPA 537.1	8/18/23
Perfluorononanoic acid (PFNA)	ND	ppt	1.9	EPA 537.1	8/18/23
Perfluorotetradecanoic acid (PFTeDA)	ND	ppt	1.9	EPA 537.1	8/18/23
Perfluorotridecanoic acid (PFTrDA)	ND	ppt	1.9	EPA 537.1	8/18/23
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND	ppt	1.9	EPA 537.1	8/18/23
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND	ppt	1.9	EPA 537.1	8/18/23
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	ND	ppt	1.9	EPA 537.1	8/18/23
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/18/23
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	ND	ppt	1.9	EPA 537.1	8/18/23
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	ND	ppt	1.9	EPA 537.1	8/18/23

- Notes:
- The EPA has issued interim health advisory levels for PFOA= 0.004ppt, PFOS= 0.02ppt; and final healthy advisory levels for GenX chemicals= 10 ppt, PFBS=2,000 ppt. The health advisory is not enforceable.
 - Samples received and examined within the EPA's recommended holding time.
 - We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.
 - ND - Not Detected.
 - ppt - parts per trillion.
 - Analyzed by Lab 209.

Reported by,



K. Wentworth, Customer Service Representative