

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**

Reporting Date: 06/06/2024  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Type: Drinking Water  
Laboratory Certification: MD-214  
Received by Lab: Date: 05/15/2024 Time: 04:58 PM  
Sampler ID: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample Id	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL (mg/L)	Analysis Date/Time
842-1	WL01 - RAW	05/15/2024 03:08 PM	Perfluorohexanoic acid (PFHxA)	NA	2.8	ppt	1.9	EPA 537.1	NA	05/23/2024 02:59 AM
842-1	WL01 - RAW	05/15/2024 03:08 PM	Perfluorooctanesulfonic acid (PFOS)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:59 AM
842-1	WL01 - RAW	05/15/2024 03:08 PM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:59 AM
842-1	WL01 - RAW	05/15/2024 03:08 PM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:59 AM
842-1	WL01 - RAW	05/15/2024 03:08 PM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:59 AM
842-1	WL01 - RAW	05/15/2024 03:08 PM	11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:59 AM
842-1	WL01 - RAW	05/15/2024 03:08 PM	Perfluorotridecanoic acid (PFTeDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:59 AM
842-1	WL01 - RAW	05/15/2024 03:08 PM	Perfluorotridecanoic acid (PFTrDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:59 AM
842-1	WL01 - RAW	05/15/2024 03:08 PM	N-methylperfluorooctanesulfonic acid (NMeFOSAA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:59 AM
842-1	WL01 - RAW	05/15/2024 03:08 PM	N-ethylperfluorooctanesulfonic acid (NEtFOSAA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:59 AM
842-1	WL01 - RAW	05/15/2024 03:08 PM	Perfluoroheptanoic acid (PFHpA)	NA	1.9	ppt	1.9	EPA 537.1	NA	05/23/2024 02:59 AM
842-1	WL01 - RAW	05/15/2024 03:08 PM	Perfluorooctanoic acid (PFOA)	NA	3.6	ppt	1.9	EPA 537.1	NA	05/23/2024 02:59 AM
842-1	WL01 - RAW	05/15/2024 03:08 PM	Perfluorononanoic acid (PFNA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:59 AM
842-1	WL01 - RAW	05/15/2024 03:08 PM	Perfluorodecanoic acid (PFDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:59 AM
842-1	WL01 - RAW	05/15/2024 03:08 PM	Perfluoroundecanoic acid (PFUnA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:59 AM
842-1	WL01 - RAW	05/15/2024 03:08 PM	Perfluorododecanoic acid (PFDoA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:59 AM
842-1	WL01 - RAW	05/15/2024 03:08 PM	Perfluorobutanesulfonic acid (PFBS)	NA	5.7	ppt	1.9	EPA 537.1	NA	05/23/2024 02:59 AM
842-1	WL01 - RAW	05/15/2024 03:08 PM	Perfluorohexanesulfonic acid (PFHxS)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:59 AM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. Sample received and examined within EPA's recommended holding time.
3. Results in **BOLD** exceed the EPA's Primary MCL.
4. SM – Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**

Reporting Date: 06/06/2024  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Type: Drinking Water  
Laboratory Certification: MD-214  
Received by Lab: Date: 05/15/2024 Time: 04:58 PM  
Sampler ID: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample Id	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL (mg/L)	Analysis Date/Time
846-1	WL02 - RAW	05/15/2024 03:09 PM	Perfluorohexanoic acid (PFHxA)	NA	5.7	ppt	1.9	EPA 537.1	NA	05/23/2024 12:31 AM
846-1	WL02 - RAW	05/15/2024 03:09 PM	Perfluorooctanesulfonic acid (PFOS)	NA	4.7	ppt	1.9	EPA 537.1	NA	05/23/2024 12:31 AM
846-1	WL02 - RAW	05/15/2024 03:09 PM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:31 AM
846-1	WL02 - RAW	05/15/2024 03:09 PM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:31 AM
846-1	WL02 - RAW	05/15/2024 03:09 PM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:31 AM
846-1	WL02 - RAW	05/15/2024 03:09 PM	11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:31 AM
846-1	WL02 - RAW	05/15/2024 03:09 PM	Perfluorotetradecanoic acid (PFTeDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:31 AM
846-1	WL02 - RAW	05/15/2024 03:09 PM	Perfluorotridecanoic acid (PFTrDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:31 AM
846-1	WL02 - RAW	05/15/2024 03:09 PM	N-methylperfluorooctanesulfonic acid (NMeFOSAA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:31 AM
846-1	WL02 - RAW	05/15/2024 03:09 PM	N-ethylperfluorooctanesulfonic acid (NEtFOSAA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:31 AM
846-1	WL02 - RAW	05/15/2024 03:09 PM	Perfluoroheptanoic acid (PFHpA)	NA	3.2	ppt	1.9	EPA 537.1	NA	05/23/2024 12:31 AM
846-1	WL02 - RAW	05/15/2024 03:09 PM	Perfluorooctanoic acid (PFOA)	NA	5.3	ppt	1.9	EPA 537.1	NA	05/23/2024 12:31 AM
846-1	WL02 - RAW	05/15/2024 03:09 PM	Perfluorononanoic acid (PFNA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:31 AM
846-1	WL02 - RAW	05/15/2024 03:09 PM	Perfluorodecanoic acid (PFDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:31 AM
846-1	WL02 - RAW	05/15/2024 03:09 PM	Perfluoroundecanoic acid (PFUnA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:31 AM
846-1	WL02 - RAW	05/15/2024 03:09 PM	Perfluorododecanoic acid (PFDoA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:31 AM
846-1	WL02 - RAW	05/15/2024 03:09 PM	Perfluorobutanesulfonic acid (PFBS)	NA	11.0	ppt	1.9	EPA 537.1	NA	05/23/2024 12:31 AM
846-1	WL02 - RAW	05/15/2024 03:09 PM	Perfluorohexanesulfonic acid (PFHxS)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:31 AM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. Sample received and examined within EPA's recommended holding time.
3. Results in **BOLD** exceed the EPA's Primary MCL.
4. SM – Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**

Reporting Date: 06/06/2024  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Type: Drinking Water  
Laboratory Certification: MD-214  
Received by Lab: Date: 05/15/2024 Time: 04:58 PM  
Sampler ID: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample Id	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL (mg/L)	Analysis Date/Time
850-1	WL03 - RAW	05/15/2024 03:03 PM	Perfluorohexanoic acid (PFHxA)	NA	2.2	ppt	1.9	EPA 537.1	NA	05/23/2024 12:42 AM
850-1	WL03 - RAW	05/15/2024 03:03 PM	Perfluorooctanesulfonic acid (PFOS)	NA	2.8	ppt	1.9	EPA 537.1	NA	05/23/2024 12:42 AM
850-1	WL03 - RAW	05/15/2024 03:03 PM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:42 AM
850-1	WL03 - RAW	05/15/2024 03:03 PM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:42 AM
850-1	WL03 - RAW	05/15/2024 03:03 PM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:42 AM
850-1	WL03 - RAW	05/15/2024 03:03 PM	11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:42 AM
850-1	WL03 - RAW	05/15/2024 03:03 PM	Perfluorotradecanoic acid (PFTeDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:42 AM
850-1	WL03 - RAW	05/15/2024 03:03 PM	Perfluorotridecanoic acid (PFTrDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:42 AM
850-1	WL03 - RAW	05/15/2024 03:03 PM	N-methylperfluorooctanesulfonic acid (NMeFOSAA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:42 AM
850-1	WL03 - RAW	05/15/2024 03:03 PM	N-ethylperfluorooctanesulfonic acid (NEtFOSAA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:42 AM
850-1	WL03 - RAW	05/15/2024 03:03 PM	Perfluoroheptanoic acid (PFHpA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:42 AM
850-1	WL03 - RAW	05/15/2024 03:03 PM	Perfluorooctanoic acid (PFOA)	NA	3.4	ppt	1.9	EPA 537.1	NA	05/23/2024 12:42 AM
850-1	WL03 - RAW	05/15/2024 03:03 PM	Perfluorononanoic acid (PFNA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:42 AM
850-1	WL03 - RAW	05/15/2024 03:03 PM	Perfluorodecanoic acid (PFDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:42 AM
850-1	WL03 - RAW	05/15/2024 03:03 PM	Perfluoroundecanoic acid (PFUnA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:42 AM
850-1	WL03 - RAW	05/15/2024 03:03 PM	Perfluorododecanoic acid (PFDoA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:42 AM
850-1	WL03 - RAW	05/15/2024 03:03 PM	Perfluorobutanesulfonic acid (PFBS)	NA	4.8	ppt	1.9	EPA 537.1	NA	05/23/2024 12:42 AM
850-1	WL03 - RAW	05/15/2024 03:03 PM	Perfluorohexanesulfonic acid (PFHxS)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:42 AM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. Sample received and examined within EPA's recommended holding time.
3. Results in **BOLD** exceed the EPA's Primary MCL.
4. SM – Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**

Reporting Date: 06/06/2024  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Type: Drinking Water  
Laboratory Certification: MD-214  
Received by Lab: Date: 05/15/2024 Time: 04:58 PM  
Sampler ID: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample Id	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL (mg/L)	Analysis Date/Time
854-1	WL04 - RAW	05/15/2024 03:04 PM	Perfluorohexanoic acid (PFHxA)	NA	6.7	ppt	1.9	EPA 537.1	NA	05/22/2024 11:59 PM
854-1	WL04 - RAW	05/15/2024 03:04 PM	Perfluorooctanesulfonic acid (PFOS)	NA	5.6	ppt	1.9	EPA 537.1	NA	05/22/2024 11:59 PM
854-1	WL04 - RAW	05/15/2024 03:04 PM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/22/2024 11:59 PM
854-1	WL04 - RAW	05/15/2024 03:04 PM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/22/2024 11:59 PM
854-1	WL04 - RAW	05/15/2024 03:04 PM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	ND	ppt	1.9	EPA 537.1	NA	05/22/2024 11:59 PM
854-1	WL04 - RAW	05/15/2024 03:04 PM	11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid	NA	ND	ppt	1.9	EPA 537.1	NA	05/22/2024 11:59 PM
854-1	WL04 - RAW	05/15/2024 03:04 PM	Perfluorotridecanoic acid (PFTeDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/22/2024 11:59 PM
854-1	WL04 - RAW	05/15/2024 03:04 PM	Perfluorotridecanoic acid (PFTrDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/22/2024 11:59 PM
854-1	WL04 - RAW	05/15/2024 03:04 PM	N-methylperfluorooctanesulfonic acid (NMeFOSAA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/22/2024 11:59 PM
854-1	WL04 - RAW	05/15/2024 03:04 PM	N-ethylperfluorooctanesulfonic acid (NEtFOSAA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/22/2024 11:59 PM
854-1	WL04 - RAW	05/15/2024 03:04 PM	Perfluoroheptanoic acid (PFHpA)	NA	3.8	ppt	1.9	EPA 537.1	NA	05/22/2024 11:59 PM
854-1	WL04 - RAW	05/15/2024 03:04 PM	Perfluorooctanoic acid (PFOA)	NA	5.7	ppt	1.9	EPA 537.1	NA	05/22/2024 11:59 PM
854-1	WL04 - RAW	05/15/2024 03:04 PM	Perfluorononanoic acid (PFNA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/22/2024 11:59 PM
854-1	WL04 - RAW	05/15/2024 03:04 PM	Perfluorodecanoic acid (PFDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/22/2024 11:59 PM
854-1	WL04 - RAW	05/15/2024 03:04 PM	Perfluoroundecanoic acid (PFUnA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/22/2024 11:59 PM
854-1	WL04 - RAW	05/15/2024 03:04 PM	Perfluorododecanoic acid (PFDoA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/22/2024 11:59 PM
854-1	WL04 - RAW	05/15/2024 03:04 PM	Perfluorobutanesulfonic acid (PFBS)	NA	14.0	ppt	1.9	EPA 537.1	NA	05/22/2024 11:59 PM
854-1	WL04 - RAW	05/15/2024 03:04 PM	Perfluorohexanesulfonic acid (PFHxS)	NA	ND	ppt	1.9	EPA 537.1	NA	05/22/2024 11:59 PM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. Sample received and examined within EPA's recommended holding time.
3. Results in **BOLD** exceed the EPA's Primary MCL.
4. SM – Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**

Reporting Date: 06/06/2024  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Type: Drinking Water  
Laboratory Certification: MD-214  
Received by Lab: Date: 05/15/2024 Time: 04:58 PM  
Sampler ID: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample Id	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL (mg/L)	Analysis Date/Time
858-1	WL05 - RAW	05/15/2024 02:07 PM	Perfluorohexanoic acid (PFHxA)	NA	4.2	ppt	1.9	EPA 537.1	NA	05/23/2024 01:56 AM
858-1	WL05 - RAW	05/15/2024 02:07 PM	Perfluorooctanesulfonic acid (PFOS)	NA	7.2	ppt	1.9	EPA 537.1	NA	05/23/2024 01:56 AM
858-1	WL05 - RAW	05/15/2024 02:07 PM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 01:56 AM
858-1	WL05 - RAW	05/15/2024 02:07 PM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 01:56 AM
858-1	WL05 - RAW	05/15/2024 02:07 PM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 01:56 AM
858-1	WL05 - RAW	05/15/2024 02:07 PM	11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 01:56 AM
858-1	WL05 - RAW	05/15/2024 02:07 PM	Perfluorotradecanoic acid (PFTeDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 01:56 AM
858-1	WL05 - RAW	05/15/2024 02:07 PM	Perfluorotridecanoic acid (PFTrDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 01:56 AM
858-1	WL05 - RAW	05/15/2024 02:07 PM	N-methylperfluorooctanesulfonic acid (NMeFOSAA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 01:56 AM
858-1	WL05 - RAW	05/15/2024 02:07 PM	N-ethylperfluorooctanesulfonic acid (NEtFOSAA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 01:56 AM
858-1	WL05 - RAW	05/15/2024 02:07 PM	Perfluoroheptanoic acid (PFHpA)	NA	2.9	ppt	1.9	EPA 537.1	NA	05/23/2024 01:56 AM
858-1	WL05 - RAW	05/15/2024 02:07 PM	Perfluorooctanoic acid (PFOA)	NA	6.2	ppt	1.9	EPA 537.1	NA	05/23/2024 01:56 AM
858-1	WL05 - RAW	05/15/2024 02:07 PM	Perfluorononanoic acid (PFNA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 01:56 AM
858-1	WL05 - RAW	05/15/2024 02:07 PM	Perfluorodecanoic acid (PFDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 01:56 AM
858-1	WL05 - RAW	05/15/2024 02:07 PM	Perfluoroundecanoic acid (PFUnA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 01:56 AM
858-1	WL05 - RAW	05/15/2024 02:07 PM	Perfluorododecanoic acid (PFDoA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 01:56 AM
858-1	WL05 - RAW	05/15/2024 02:07 PM	Perfluorobutanesulfonic acid (PFBS)	NA	6.5	ppt	1.9	EPA 537.1	NA	05/23/2024 01:56 AM
858-1	WL05 - RAW	05/15/2024 02:07 PM	Perfluorohexanesulfonic acid (PFHxS)	NA	1.9	ppt	1.9	EPA 537.1	NA	05/23/2024 01:56 AM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. Sample received and examined within EPA's recommended holding time.
3. Results in **BOLD** exceed the EPA's Primary MCL.
4. SM – Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**

Reporting Date: 06/06/2024  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Type: Drinking Water  
Laboratory Certification: MD-214  
Received by Lab: Date: 05/15/2024 Time: 04:58 PM  
Sampler ID: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample Id	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL (mg/L)	Analysis Date/Time
862-1	WL06 - RAW	05/15/2024 02:06 PM	Perfluorohexanoic acid (PFHxA)	NA	4.4	ppt	1.9	EPA 537.1	NA	05/23/2024 02:07 AM
862-1	WL06 - RAW	05/15/2024 02:06 PM	Perfluorooctanesulfonic acid (PFOS)	NA	7.0	ppt	1.9	EPA 537.1	NA	05/23/2024 02:07 AM
862-1	WL06 - RAW	05/15/2024 02:06 PM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:07 AM
862-1	WL06 - RAW	05/15/2024 02:06 PM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:07 AM
862-1	WL06 - RAW	05/15/2024 02:06 PM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:07 AM
862-1	WL06 - RAW	05/15/2024 02:06 PM	11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:07 AM
862-1	WL06 - RAW	05/15/2024 02:06 PM	Perfluorotradecanoic acid (PFTeDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:07 AM
862-1	WL06 - RAW	05/15/2024 02:06 PM	Perfluorotridecanoic acid (PFTrDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:07 AM
862-1	WL06 - RAW	05/15/2024 02:06 PM	N-methylperfluorooctanesulfonic acid (NMeFOSAA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:07 AM
862-1	WL06 - RAW	05/15/2024 02:06 PM	N-ethylperfluorooctanesulfonic acid (NEtFOSAA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:07 AM
862-1	WL06 - RAW	05/15/2024 02:06 PM	Perfluoroheptanoic acid (PFHpA)	NA	2.8	ppt	1.9	EPA 537.1	NA	05/23/2024 02:07 AM
862-1	WL06 - RAW	05/15/2024 02:06 PM	Perfluorooctanoic acid (PFOA)	NA	5.8	ppt	1.9	EPA 537.1	NA	05/23/2024 02:07 AM
862-1	WL06 - RAW	05/15/2024 02:06 PM	Perfluorononanoic acid (PFNA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:07 AM
862-1	WL06 - RAW	05/15/2024 02:06 PM	Perfluorodecanoic acid (PFDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:07 AM
862-1	WL06 - RAW	05/15/2024 02:06 PM	Perfluoroundecanoic acid (PFUnA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:07 AM
862-1	WL06 - RAW	05/15/2024 02:06 PM	Perfluorododecanoic acid (PFDoA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:07 AM
862-1	WL06 - RAW	05/15/2024 02:06 PM	Perfluorobutanesulfonic acid (PFBS)	NA	6.0	ppt	1.9	EPA 537.1	NA	05/23/2024 02:07 AM
862-1	WL06 - RAW	05/15/2024 02:06 PM	Perfluorohexanesulfonic acid (PFHxS)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:07 AM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. Sample received and examined within EPA's recommended holding time.
3. Results in **BOLD** exceed the EPA's Primary MCL.
4. SM – Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**

Reporting Date: 06/06/2024  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Type: Drinking Water  
Laboratory Certification: MD-214  
Received by Lab: Date: 05/15/2024 Time: 04:58 PM  
Sampler ID: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample Id	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL (mg/L)	Analysis Date/Time
866-1	WL07 - RAW	05/15/2024 02:42 PM	Perfluorohexanoic acid (PFHxA)	NA	29.0	ppt	1.9	EPA 537.1	NA	05/23/2024 02:17 AM
866-1	WL07 - RAW	05/15/2024 02:42 PM	Perfluorooctanesulfonic acid (PFOS)	NA	4.6	ppt	1.9	EPA 537.1	NA	05/23/2024 02:17 AM
866-1	WL07 - RAW	05/15/2024 02:42 PM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:17 AM
866-1	WL07 - RAW	05/15/2024 02:42 PM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:17 AM
866-1	WL07 - RAW	05/15/2024 02:42 PM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:17 AM
866-1	WL07 - RAW	05/15/2024 02:42 PM	11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:17 AM
866-1	WL07 - RAW	05/15/2024 02:42 PM	Perfluorotetradecanoic acid (PFTeDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:17 AM
866-1	WL07 - RAW	05/15/2024 02:42 PM	Perfluorotridecanoic acid (PFTrDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:17 AM
866-1	WL07 - RAW	05/15/2024 02:42 PM	N-methylperfluorooctanesulfonic acid (NMeFOSAA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:17 AM
866-1	WL07 - RAW	05/15/2024 02:42 PM	N-ethylperfluorooctanesulfonic acid (NEtFOSAA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:17 AM
866-1	WL07 - RAW	05/15/2024 02:42 PM	Perfluoroheptanoic acid (PFHpA)	NA	10.0	ppt	1.9	EPA 537.1	NA	05/23/2024 02:17 AM
866-1	WL07 - RAW	05/15/2024 02:42 PM	Perfluorooctanoic acid (PFOA)	NA	19.0	ppt	1.9	EPA 537.1	NA	05/23/2024 02:17 AM
866-1	WL07 - RAW	05/15/2024 02:42 PM	Perfluorononanoic acid (PFNA)	NA	2.1	ppt	1.9	EPA 537.1	NA	05/23/2024 02:17 AM
866-1	WL07 - RAW	05/15/2024 02:42 PM	Perfluorodecanoic acid (PFDA)	NA	3.7	ppt	1.9	EPA 537.1	NA	05/23/2024 02:17 AM
866-1	WL07 - RAW	05/15/2024 02:42 PM	Perfluoroundecanoic acid (PFUnA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:17 AM
866-1	WL07 - RAW	05/15/2024 02:42 PM	Perfluorododecanoic acid (PFDoA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:17 AM
866-1	WL07 - RAW	05/15/2024 02:42 PM	Perfluorobutanesulfonic acid (PFBS)	NA	2.6	ppt	1.9	EPA 537.1	NA	05/23/2024 02:17 AM
866-1	WL07 - RAW	05/15/2024 02:42 PM	Perfluorohexanesulfonic acid (PFHxS)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:17 AM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. Sample received and examined within EPA's recommended holding time.
3. Results in **BOLD** exceed the EPA's Primary MCL.
4. SM – Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**

Reporting Date: 06/06/2024  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Type: Drinking Water  
Laboratory Certification: MD-214  
Received by Lab: Date: 05/15/2024 Time: 04:58 PM  
Sampler ID: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample Id	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL (mg/L)	Analysis Date/Time
870-1	WL08 - RAW	05/15/2024 02:15 PM	Perfluorohexanoic acid (PFHxA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:28 AM
870-1	WL08 - RAW	05/15/2024 02:15 PM	Perfluorooctanesulfonic acid (PFOS)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:28 AM
870-1	WL08 - RAW	05/15/2024 02:15 PM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:28 AM
870-1	WL08 - RAW	05/15/2024 02:15 PM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:28 AM
870-1	WL08 - RAW	05/15/2024 02:15 PM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:28 AM
870-1	WL08 - RAW	05/15/2024 02:15 PM	11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:28 AM
870-1	WL08 - RAW	05/15/2024 02:15 PM	Perfluorotradecanoic acid (PFTeDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:28 AM
870-1	WL08 - RAW	05/15/2024 02:15 PM	Perfluorotridecanoic acid (PFTrDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:28 AM
870-1	WL08 - RAW	05/15/2024 02:15 PM	N-methylperfluorooctanesulfonic acid (NMeFOSAA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:28 AM
870-1	WL08 - RAW	05/15/2024 02:15 PM	N-ethylperfluorooctanesulfonic acid (NEtFOSAA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:28 AM
870-1	WL08 - RAW	05/15/2024 02:15 PM	Perfluoroheptanoic acid (PFHpA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:28 AM
870-1	WL08 - RAW	05/15/2024 02:15 PM	Perfluorooctanoic acid (PFOA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:28 AM
870-1	WL08 - RAW	05/15/2024 02:15 PM	Perfluorononanoic acid (PFNA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:28 AM
870-1	WL08 - RAW	05/15/2024 02:15 PM	Perfluorodecanoic acid (PFDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:28 AM
870-1	WL08 - RAW	05/15/2024 02:15 PM	Perfluoroundecanoic acid (PFUnA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:28 AM
870-1	WL08 - RAW	05/15/2024 02:15 PM	Perfluorododecanoic acid (PFDoA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:28 AM
870-1	WL08 - RAW	05/15/2024 02:15 PM	Perfluorobutanesulfonic acid (PFBS)	NA	2.0	ppt	1.9	EPA 537.1	NA	05/23/2024 02:28 AM
870-1	WL08 - RAW	05/15/2024 02:15 PM	Perfluorohexanesulfonic acid (PFHxS)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 02:28 AM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. Sample received and examined within EPA's recommended holding time.
3. Results in **BOLD** exceed the EPA's Primary MCL.
4. SM – Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**

Reporting Date: 06/06/2024  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Type: Drinking Water  
Laboratory Certification: MD-214  
Received by Lab: Date: 05/15/2024 Time: 04:58 PM  
Sampler ID: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample Id	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL (mg/L)	Analysis Date/Time
874-1	WL09 - RAW	05/15/2024 02:54 PM	Perfluorohexanoic acid (PFHxA)	NA	3.7	ppt	2.0	EPA 537.1	NA	05/23/2024 02:38 AM
874-1	WL09 - RAW	05/15/2024 02:54 PM	Perfluorooctanesulfonic acid (PFOS)	NA	ND	ppt	2.0	EPA 537.1	NA	05/23/2024 02:38 AM
874-1	WL09 - RAW	05/15/2024 02:54 PM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	NA	ND	ppt	2.0	EPA 537.1	NA	05/23/2024 02:38 AM
874-1	WL09 - RAW	05/15/2024 02:54 PM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	ND	ppt	2.0	EPA 537.1	NA	05/23/2024 02:38 AM
874-1	WL09 - RAW	05/15/2024 02:54 PM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	ND	ppt	2.0	EPA 537.1	NA	05/23/2024 02:38 AM
874-1	WL09 - RAW	05/15/2024 02:54 PM	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	NA	ND	ppt	2.0	EPA 537.1	NA	05/23/2024 02:38 AM
874-1	WL09 - RAW	05/15/2024 02:54 PM	Perfluorotetradecanoic acid (PFTeDA)	NA	ND	ppt	2.0	EPA 537.1	NA	05/23/2024 02:38 AM
874-1	WL09 - RAW	05/15/2024 02:54 PM	Perfluorotridecanoic acid (PFTrDA)	NA	ND	ppt	2.0	EPA 537.1	NA	05/23/2024 02:38 AM
874-1	WL09 - RAW	05/15/2024 02:54 PM	N-methylperfluorooctanesulfonic acid (NMeFOSAA)	NA	ND	ppt	2.0	EPA 537.1	NA	05/23/2024 02:38 AM
874-1	WL09 - RAW	05/15/2024 02:54 PM	N-ethylperfluorooctanesulfonic acid (NEtFOSAA)	NA	ND	ppt	2.0	EPA 537.1	NA	05/23/2024 02:38 AM
874-1	WL09 - RAW	05/15/2024 02:54 PM	Perfluoroheptanoic acid (PFHpA)	NA	ND	ppt	2.0	EPA 537.1	NA	05/23/2024 02:38 AM
874-1	WL09 - RAW	05/15/2024 02:54 PM	Perfluorooctanoic acid (PFOA)	NA	3.5	ppt	2.0	EPA 537.1	NA	05/23/2024 02:38 AM
874-1	WL09 - RAW	05/15/2024 02:54 PM	Perfluorononanoic acid (PFNA)	NA	ND	ppt	2.0	EPA 537.1	NA	05/23/2024 02:38 AM
874-1	WL09 - RAW	05/15/2024 02:54 PM	Perfluorodecanoic acid (PFDA)	NA	ND	ppt	2.0	EPA 537.1	NA	05/23/2024 02:38 AM
874-1	WL09 - RAW	05/15/2024 02:54 PM	Perfluoroundecanoic acid (PFUnA)	NA	ND	ppt	2.0	EPA 537.1	NA	05/23/2024 02:38 AM
874-1	WL09 - RAW	05/15/2024 02:54 PM	Perfluorododecanoic acid (PFDoA)	NA	ND	ppt	2.0	EPA 537.1	NA	05/23/2024 02:38 AM
874-1	WL09 - RAW	05/15/2024 02:54 PM	Perfluorobutanesulfonic acid (PFBS)	NA	2.0	ppt	2.0	EPA 537.1	NA	05/23/2024 02:38 AM
874-1	WL09 - RAW	05/15/2024 02:54 PM	Perfluorohexanesulfonic acid (PFHxS)	NA	ND	ppt	2.0	EPA 537.1	NA	05/23/2024 02:38 AM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. Sample received and examined within EPA's recommended holding time.
3. Results in **BOLD** exceed the EPA's Primary MCL.
4. SM – Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**

Reporting Date: 06/06/2024  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Type: Drinking Water  
Laboratory Certification: MD-214  
Received by Lab: Date: 05/15/2024 Time: 04:58 PM  
Sampler ID: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample Id	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL (mg/L)	Analysis Date/Time
878-1	WL010 - RAW	05/15/2024 02:21 PM	Perfluorohexanoic acid (PFHxA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:52 AM
878-1	WL010 - RAW	05/15/2024 02:21 PM	Perfluorooctanesulfonic acid (PFOS)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:52 AM
878-1	WL010 - RAW	05/15/2024 02:21 PM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:52 AM
878-1	WL010 - RAW	05/15/2024 02:21 PM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:52 AM
878-1	WL010 - RAW	05/15/2024 02:21 PM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:52 AM
878-1	WL010 - RAW	05/15/2024 02:21 PM	11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:52 AM
878-1	WL010 - RAW	05/15/2024 02:21 PM	Perfluorotradecanoic acid (PFTeDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:52 AM
878-1	WL010 - RAW	05/15/2024 02:21 PM	Perfluorotridecanoic acid (PFTrDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:52 AM
878-1	WL010 - RAW	05/15/2024 02:21 PM	N-methylperfluorooctanesulfonic acid (NMeFOSAA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:52 AM
878-1	WL010 - RAW	05/15/2024 02:21 PM	N-ethylperfluorooctanesulfonic acid (NEtFOSAA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:52 AM
878-1	WL010 - RAW	05/15/2024 02:21 PM	Perfluoroheptanoic acid (PFHpA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:52 AM
878-1	WL010 - RAW	05/15/2024 02:21 PM	Perfluorooctanoic acid (PFOA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:52 AM
878-1	WL010 - RAW	05/15/2024 02:21 PM	Perfluorononanoic acid (PFNA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:52 AM
878-1	WL010 - RAW	05/15/2024 02:21 PM	Perfluorodecanoic acid (PFDA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:52 AM
878-1	WL010 - RAW	05/15/2024 02:21 PM	Perfluoroundecanoic acid (PFUnA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:52 AM
878-1	WL010 - RAW	05/15/2024 02:21 PM	Perfluorododecanoic acid (PFDoA)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:52 AM
878-1	WL010 - RAW	05/15/2024 02:21 PM	Perfluorobutanesulfonic acid (PFBS)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:52 AM
878-1	WL010 - RAW	05/15/2024 02:21 PM	Perfluorohexanesulfonic acid (PFHxS)	NA	ND	ppt	1.9	EPA 537.1	NA	05/23/2024 12:52 AM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. Sample received and examined within EPA's recommended holding time.
3. Results in **BOLD** exceed the EPA's Primary MCL.
4. SM – Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**

Reporting Date: 06/06/2024  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Type: Drinking Water  
Laboratory Certification: MD-214  
Received by Lab: Date: 05/22/2024 Time: 04:46 PM  
Sampler ID: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample Id	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL (mg/L)	Analysis Date/Time
882-1	WL011 - RAW	05/22/2024 01:30 PM	Perfluorohexanoic acid (PFHxA)	NA	2.1	ppt	2.0	EPA 537.1	NA	06/05/2024 12:39 AM
882-1	WL011 - RAW	05/22/2024 01:30 PM	Perfluorooctanesulfonic acid (PFOS)	NA	3.5	ppt	2.0	EPA 537.1	NA	06/05/2024 12:39 AM
882-1	WL011 - RAW	05/22/2024 01:30 PM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	NA	ND	ppt	2.0	EPA 537.1	NA	06/05/2024 12:39 AM
882-1	WL011 - RAW	05/22/2024 01:30 PM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	ND	ppt	2.0	EPA 537.1	NA	06/05/2024 12:39 AM
882-1	WL011 - RAW	05/22/2024 01:30 PM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	ND	ppt	2.0	EPA 537.1	NA	06/05/2024 12:39 AM
882-1	WL011 - RAW	05/22/2024 01:30 PM	11-Chloroeicosafafluoro-3-oxaundecane-1-sulfonic acid	NA	ND	ppt	2.0	EPA 537.1	NA	06/05/2024 12:39 AM
882-1	WL011 - RAW	05/22/2024 01:30 PM	Perfluorotetradecanoic acid (PFTeDA)	NA	ND	ppt	2.0	EPA 537.1	NA	06/05/2024 12:39 AM
882-1	WL011 - RAW	05/22/2024 01:30 PM	Perfluorotridecanoic acid (PFTrDA)	NA	ND	ppt	2.0	EPA 537.1	NA	06/05/2024 12:39 AM
882-1	WL011 - RAW	05/22/2024 01:30 PM	N-methylperfluorooctanesulfonic acid (NMeFOSAA)	NA	ND	ppt	2.0	EPA 537.1	NA	06/05/2024 12:39 AM
882-1	WL011 - RAW	05/22/2024 01:30 PM	N-ethylperfluorooctanesulfonic acid (NEtFOSAA)	NA	ND	ppt	2.0	EPA 537.1	NA	06/05/2024 12:39 AM
882-1	WL011 - RAW	05/22/2024 01:30 PM	Perfluoroheptanoic acid (PFHpA)	NA	ND	ppt	2.0	EPA 537.1	NA	06/05/2024 12:39 AM
882-1	WL011 - RAW	05/22/2024 01:30 PM	Perfluorooctanoic acid (PFOA)	NA	2.9	ppt	2.0	EPA 537.1	NA	06/05/2024 12:39 AM
882-1	WL011 - RAW	05/22/2024 01:30 PM	Perfluorononanoic acid (PFNA)	NA	ND	ppt	2.0	EPA 537.1	NA	06/05/2024 12:39 AM
882-1	WL011 - RAW	05/22/2024 01:30 PM	Perfluorodecanoic acid (PFDA)	NA	ND	ppt	2.0	EPA 537.1	NA	06/05/2024 12:39 AM
882-1	WL011 - RAW	05/22/2024 01:30 PM	Perfluoroundecanoic acid (PFUnA)	NA	ND	ppt	2.0	EPA 537.1	NA	06/05/2024 12:39 AM
882-1	WL011 - RAW	05/22/2024 01:30 PM	Perfluorododecanoic acid (PFDoA)	NA	ND	ppt	2.0	EPA 537.1	NA	06/05/2024 12:39 AM
882-1	WL011 - RAW	05/22/2024 01:30 PM	Perfluorobutanesulfonic acid (PFBS)	NA	2.0	ppt	2.0	EPA 537.1	NA	06/05/2024 12:39 AM
882-1	WL011 - RAW	05/22/2024 01:30 PM	Perfluorohexanesulfonic acid (PFHxS)	NA	ND	ppt	2.0	EPA 537.1	NA	06/05/2024 12:39 AM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. Sample received and examined within EPA's recommended holding time.
3. Results in **BOLD** exceed the EPA's Primary MCL.
4. SM – Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.