

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**

Reporting Date: 12/08/2025  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Address: 000 Ridge Road Mt Airy, MD 21771  
Sample Type: Drinking Water  
Laboratory Certification: #214 Maryland, #134 Maryland, #00107 Virginia  
Received by Lab: Date: 11/24/2025 Time: 04:34 PM  
Sampler: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample ID	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL	Analysis Date/Time
15497-1	WL09 - RAW	11/24/2025 12:01 PM	Perfluorohexanoic Acid (PFHXA)	NA	3.7	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:04 PM
15497-1	WL09 - RAW	11/24/2025 12:01 PM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	2816	<1.9	ng/L	1.9	EPA 537.1	10	12/03/2025 07:04 PM
15497-1	WL09 - RAW	11/24/2025 12:01 PM	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:04 PM
15497-1	WL09 - RAW	11/24/2025 12:01 PM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:04 PM
15497-1	WL09 - RAW	11/24/2025 12:01 PM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:04 PM
15497-1	WL09 - RAW	11/24/2025 12:01 PM	Perfluorotetradecanoic acid (PFTeDA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:04 PM
15497-1	WL09 - RAW	11/24/2025 12:01 PM	Perfluorotridecanoic acid (PFTrDA)	NA	<1.9	ppt	1.9	EPA 537.1	NA	12/03/2025 07:04 PM
15497-1	WL09 - RAW	11/24/2025 12:01 PM	N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:04 PM
15497-1	WL09 - RAW	11/24/2025 12:01 PM	N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:04 PM
15497-1	WL09 - RAW	11/24/2025 12:01 PM	Perfluoroheptanoic acid (PFHpA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:04 PM
15497-1	WL09 - RAW	11/24/2025 12:01 PM	Perfluorooctanoic acid (PFOA)	2806	2.8	ng/L	1.9	EPA 537.1	4	12/03/2025 07:04 PM
15497-1	WL09 - RAW	11/24/2025 12:01 PM	Perfluorononanoic acid (PFNA)	2804	<1.9	ng/L	1.9	EPA 537.1	10	12/03/2025 07:04 PM
15497-1	WL09 - RAW	11/24/2025 12:01 PM	Perfluorodecanoic acid (PFDA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:04 PM
15497-1	WL09 - RAW	11/24/2025 12:01 PM	Perfluoroundecanoic Acid (PFUNA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:04 PM
15497-1	WL09 - RAW	11/24/2025 12:01 PM	Perfluorododecanoic acid (PFDoA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:04 PM
15497-1	WL09 - RAW	11/24/2025 12:01 PM	Perfluorobutanesulfonic acid (PFBS)	2801	2.1	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:04 PM
15497-1	WL09 - RAW	11/24/2025 12:01 PM	Perfluorohexanesulfonic acid (PFHxS)	2803	<1.9	ng/L	1.9	EPA 537.1	10	12/03/2025 07:04 PM
15497-1	WL09 - RAW	11/24/2025 12:01 PM	Perfluorooctanesulfonic Acid (PFOS)	2805	<1.9	ng/L	1.9	EPA 537.1	4	12/03/2025 07:04 PM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. EPA finalized a National Primary Drinking Water Regulation (NPDWR) establishing legally enforceable levels, called Maximum Contaminant Levels (MCLs), for six PFAS in drinking water. PFOA, PFOS, PFHxS, PFNA, and HFPO-DA as contaminants with

individual MCLs, and PFAS mixtures containing at least two or more of PFHxS, PFNA, HFPO-DA, and PFBS using a Hazard Index MCL to account for the combined and co-occurring levels of these PFAS in drinking water. EPA also finalized health-based, non-enforceable Maximum Contaminant Level Goals (MCLGs) for these PFAS.

3. ng/L is equivalent to parts per trillion
4. Sample received and examined within EPA's recommended holding time.
5. Results in **BOLD** exceed the EPA's MCL.
6. SM - Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.
7. NA - Not Applicable.
8. The following tests were analyzed in other labs: PFAS 537.1 was analyzed by lab MD-209.
9. We certify that the analyses performed for this report are accurate and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.

Reported by,

*T. Davis*

T. Davis, Customer Service Representative

Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771

Reporting Date: 12/08/2025  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Address: 000 Ridge Road Mt Airy, MD 21771  
Sample Type: Drinking Water  
Laboratory Certification: #214 Maryland, #134 Maryland, #00107 Virginia  
Received by Lab: Date: 11/24/2025 Time: 04:34 PM  
Sampler: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample ID	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL	Analysis Date/Time
15644-1	WL05 - RAW	11/24/2025 11:04 AM	Perfluorohexanoic Acid (PFHXA)	NA	4.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:35 PM
15644-1	WL05 - RAW	11/24/2025 11:04 AM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	2816	<1.9	ng/L	1.9	EPA 537.1	10	12/03/2025 07:35 PM
15644-1	WL05 - RAW	11/24/2025 11:04 AM	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:35 PM
15644-1	WL05 - RAW	11/24/2025 11:04 AM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:35 PM
15644-1	WL05 - RAW	11/24/2025 11:04 AM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:35 PM
15644-1	WL05 - RAW	11/24/2025 11:04 AM	Perfluorotetradecanoic acid (PFTeDA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:35 PM
15644-1	WL05 - RAW	11/24/2025 11:04 AM	Perfluorotridecanoic acid (PFTrDA)	NA	<1.9	ppt	1.9	EPA 537.1	NA	12/03/2025 07:35 PM
15644-1	WL05 - RAW	11/24/2025 11:04 AM	N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:35 PM
15644-1	WL05 - RAW	11/24/2025 11:04 AM	N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:35 PM
15644-1	WL05 - RAW	11/24/2025 11:04 AM	Perfluoroheptanoic acid (PFHpA)	NA	3.1	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:35 PM
15644-1	WL05 - RAW	11/24/2025 11:04 AM	Perfluorooctanoic acid (PFOA)	2806	<b>6.5</b>	ng/L	1.9	EPA 537.1	4	12/03/2025 07:35 PM
15644-1	WL05 - RAW	11/24/2025 11:04 AM	Perfluorononanoic acid (PFNA)	2804	<1.9	ng/L	1.9	EPA 537.1	10	12/03/2025 07:35 PM
15644-1	WL05 - RAW	11/24/2025 11:04 AM	Perfluorodecanoic acid (PFDA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:35 PM
15644-1	WL05 - RAW	11/24/2025 11:04 AM	Perfluoroundecanoic Acid (PFUNA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:35 PM
15644-1	WL05 - RAW	11/24/2025 11:04 AM	Perfluorododecanoic acid (PFDoA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:35 PM
15644-1	WL05 - RAW	11/24/2025 11:04 AM	Perfluorobutanesulfonic acid (PFBS)	2801	7.3	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:35 PM
15644-1	WL05 - RAW	11/24/2025 11:04 AM	Perfluorohexanesulfonic acid (PFHxS)	2803	2.3	ng/L	1.9	EPA 537.1	10	12/03/2025 07:35 PM
15644-1	WL05 - RAW	11/24/2025 11:04 AM	Perfluorooctanesulfonic Acid (PFOS)	2805	<b>7.0</b>	ng/L	1.9	EPA 537.1	4	12/03/2025 07:35 PM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. EPA finalized a National Primary Drinking Water Regulation (NPDWR) establishing legally enforceable levels, called Maximum Contaminant Levels (MCLs), for six PFAS in drinking water. PFOA, PFOS, PFHxS, PFNA, and HFPO-DA as contaminants with

individual MCLs, and PFAS mixtures containing at least two or more of PFHxS, PFNA, HFPO-DA, and PFBS using a Hazard Index MCL to account for the combined and co-occurring levels of these PFAS in drinking water. EPA also finalized health-based, non-enforceable Maximum Contaminant Level Goals (MCLGs) for these PFAS.

3. ng/L is equivalent to parts per trillion
4. Sample received and examined within EPA's recommended holding time.
5. Results in **BOLD** exceed the EPA's MCL.
6. SM - Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.
7. NA - Not Applicable.
8. The following tests were analyzed in other labs: PFAS 537.1 was analyzed by lab MD-209.
9. We certify that the analyses performed for this report are accurate and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.

Reported by,

*T. Davis*

T. Davis, Customer Service Representative

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**

Reporting Date: 12/08/2025  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Address: 000 Ridge Road Mt Airy, MD 21771  
Sample Type: Drinking Water  
Laboratory Certification: #214 Maryland, #134 Maryland, #00107 Virginia  
Received by Lab: Date: 11/24/2025 Time: 04:34 PM  
Sampler: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample ID	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL	Analysis Date/Time
15712-1	WL08 - RAW	11/24/2025 11:25 AM	Perfluorohexanoic Acid (PFHXA)	NA	1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:07 PM
15712-1	WL08 - RAW	11/24/2025 11:25 AM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	2816	<1.9	ng/L	1.9	EPA 537.1	10	12/03/2025 08:07 PM
15712-1	WL08 - RAW	11/24/2025 11:25 AM	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:07 PM
15712-1	WL08 - RAW	11/24/2025 11:25 AM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:07 PM
15712-1	WL08 - RAW	11/24/2025 11:25 AM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:07 PM
15712-1	WL08 - RAW	11/24/2025 11:25 AM	Perfluorotetradecanoic acid (PFTeDA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:07 PM
15712-1	WL08 - RAW	11/24/2025 11:25 AM	Perfluorotridecanoic acid (PFTrDA)	NA	<1.9	ppt	1.9	EPA 537.1	NA	12/03/2025 08:07 PM
15712-1	WL08 - RAW	11/24/2025 11:25 AM	N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:07 PM
15712-1	WL08 - RAW	11/24/2025 11:25 AM	N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:07 PM
15712-1	WL08 - RAW	11/24/2025 11:25 AM	Perfluoroheptanoic acid (PFHpA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:07 PM
15712-1	WL08 - RAW	11/24/2025 11:25 AM	Perfluorooctanoic acid (PFOA)	2806	<1.9	ng/L	1.9	EPA 537.1	4	12/03/2025 08:07 PM
15712-1	WL08 - RAW	11/24/2025 11:25 AM	Perfluorononanoic acid (PFNA)	2804	<1.9	ng/L	1.9	EPA 537.1	10	12/03/2025 08:07 PM
15712-1	WL08 - RAW	11/24/2025 11:25 AM	Perfluorodecanoic acid (PFDA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:07 PM
15712-1	WL08 - RAW	11/24/2025 11:25 AM	Perfluoroundecanoic Acid (PFUNA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:07 PM
15712-1	WL08 - RAW	11/24/2025 11:25 AM	Perfluorododecanoic acid (PFDoA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:07 PM
15712-1	WL08 - RAW	11/24/2025 11:25 AM	Perfluorobutanesulfonic acid (PFBS)	2801	2.0	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:07 PM
15712-1	WL08 - RAW	11/24/2025 11:25 AM	Perfluorohexanesulfonic acid (PFHxS)	2803	<1.9	ng/L	1.9	EPA 537.1	10	12/03/2025 08:07 PM
15712-1	WL08 - RAW	11/24/2025 11:25 AM	Perfluorooctanesulfonic Acid (PFOS)	2805	<1.9	ng/L	1.9	EPA 537.1	4	12/03/2025 08:07 PM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. EPA finalized a National Primary Drinking Water Regulation (NPDWR) establishing legally enforceable levels, called Maximum Contaminant Levels (MCLs), for six PFAS in drinking water. PFOA, PFOS, PFHxS, PFNA, and HFPO-DA as contaminants with

individual MCLs, and PFAS mixtures containing at least two or more of PFHxS, PFNA, HFPO-DA, and PFBS using a Hazard Index MCL to account for the combined and co-occurring levels of these PFAS in drinking water. EPA also finalized health-based, non-enforceable Maximum Contaminant Level Goals (MCLGs) for these PFAS.

3. ng/L is equivalent to parts per trillion
4. Sample received and examined within EPA's recommended holding time.
5. Results in **BOLD** exceed the EPA's MCL.
6. SM - Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.
7. NA - Not Applicable.
8. The following tests were analyzed in other labs: PFAS 537.1 was analyzed by lab MD-209.
9. We certify that the analyses performed for this report are accurate and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.

Reported by,

*T. Davis*

T. Davis, Customer Service Representative

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**

Reporting Date: 12/08/2025  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Address: 000 Ridge Road Mt Airy, MD 21771  
Sample Type: Drinking Water  
Laboratory Certification: #214 Maryland, #134 Maryland, #00107 Virginia  
Received by Lab: Date: 11/24/2025 Time: 04:34 PM  
Sampler: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample ID	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL	Analysis Date/Time
15807-1	WL02 - RAW	11/24/2025 11:45 AM	Perfluorohexanoic Acid (PFHXA)	NA	7.1	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:28 PM
15807-1	WL02 - RAW	11/24/2025 11:45 AM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	2816	<2.0	ng/L	2.0	EPA 537.1	10	12/03/2025 08:28 PM
15807-1	WL02 - RAW	11/24/2025 11:45 AM	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:28 PM
15807-1	WL02 - RAW	11/24/2025 11:45 AM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:28 PM
15807-1	WL02 - RAW	11/24/2025 11:45 AM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:28 PM
15807-1	WL02 - RAW	11/24/2025 11:45 AM	Perfluorotetradecanoic acid (PFTeDA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:28 PM
15807-1	WL02 - RAW	11/24/2025 11:45 AM	Perfluorotridecanoic acid (PFTrDA)	NA	<2.0	ppt	2.0	EPA 537.1	NA	12/03/2025 08:28 PM
15807-1	WL02 - RAW	11/24/2025 11:45 AM	N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:28 PM
15807-1	WL02 - RAW	11/24/2025 11:45 AM	N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:28 PM
15807-1	WL02 - RAW	11/24/2025 11:45 AM	Perfluoroheptanoic acid (PFHpA)	NA	3.3	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:28 PM
15807-1	WL02 - RAW	11/24/2025 11:45 AM	Perfluorooctanoic acid (PFOA)	2806	<b>4.9</b>	ng/L	2.0	EPA 537.1	4	12/03/2025 08:28 PM
15807-1	WL02 - RAW	11/24/2025 11:45 AM	Perfluorononanoic acid (PFNA)	2804	<2.0	ng/L	2.0	EPA 537.1	10	12/03/2025 08:28 PM
15807-1	WL02 - RAW	11/24/2025 11:45 AM	Perfluorodecanoic acid (PFDA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:28 PM
15807-1	WL02 - RAW	11/24/2025 11:45 AM	Perfluoroundecanoic Acid (PFUNA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:28 PM
15807-1	WL02 - RAW	11/24/2025 11:45 AM	Perfluorododecanoic acid (PFDoA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:28 PM
15807-1	WL02 - RAW	11/24/2025 11:45 AM	Perfluorobutanesulfonic acid (PFBS)	2801	16.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:28 PM
15807-1	WL02 - RAW	11/24/2025 11:45 AM	Perfluorohexanesulfonic acid (PFHxS)	2803	<2.0	ng/L	2.0	EPA 537.1	10	12/03/2025 08:28 PM
15807-1	WL02 - RAW	11/24/2025 11:45 AM	Perfluorooctanesulfonic Acid (PFOS)	2805	<b>4.3</b>	ng/L	2.0	EPA 537.1	4	12/03/2025 08:28 PM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. EPA finalized a National Primary Drinking Water Regulation (NPDWR) establishing legally enforceable levels, called Maximum Contaminant Levels (MCLs), for six PFAS in drinking water. PFOA, PFOS, PFHxS, PFNA, and HFPO-DA as contaminants with

individual MCLs, and PFAS mixtures containing at least two or more of PFHxS, PFNA, HFPO-DA, and PFBS using a Hazard Index MCL to account for the combined and co-occurring levels of these PFAS in drinking water. EPA also finalized health-based, non-enforceable Maximum Contaminant Level Goals (MCLGs) for these PFAS.

3. ng/L is equivalent to parts per trillion
4. Sample received and examined within EPA's recommended holding time.
5. Results in **BOLD** exceed the EPA's MCL.
6. SM - Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.
7. NA - Not Applicable.
8. The following tests were analyzed in other labs: PFAS 537.1 was analyzed by lab MD-209.
9. We certify that the analyses performed for this report are accurate and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.

Reported by,

*T. Davis*

T. Davis, Customer Service Representative

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**

Reporting Date: 12/08/2025  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Address: 000 Ridge Road Mt Airy, MD 21771  
Sample Type: Drinking Water  
Laboratory Certification: #214 Maryland, #134 Maryland, #00107 Virginia  
Received by Lab: Date: 11/24/2025 Time: 04:34 PM  
Sampler: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample ID	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL	Analysis Date/Time
15785-1	WL011 - RAW	11/24/2025 12:21 PM	Perfluorohexanoic Acid (PFHXA)	NA	2.1	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:17 PM
15785-1	WL011 - RAW	11/24/2025 12:21 PM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	2816	<2.0	ng/L	2.0	EPA 537.1	10	12/03/2025 08:17 PM
15785-1	WL011 - RAW	11/24/2025 12:21 PM	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:17 PM
15785-1	WL011 - RAW	11/24/2025 12:21 PM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:17 PM
15785-1	WL011 - RAW	11/24/2025 12:21 PM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:17 PM
15785-1	WL011 - RAW	11/24/2025 12:21 PM	Perfluorotetradecanoic acid (PFTeDA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:17 PM
15785-1	WL011 - RAW	11/24/2025 12:21 PM	Perfluorotridecanoic acid (PFTrDA)	NA	<2.0	ppt	2.0	EPA 537.1	NA	12/03/2025 08:17 PM
15785-1	WL011 - RAW	11/24/2025 12:21 PM	N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:17 PM
15785-1	WL011 - RAW	11/24/2025 12:21 PM	N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:17 PM
15785-1	WL011 - RAW	11/24/2025 12:21 PM	Perfluoroheptanoic acid (PFHpA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:17 PM
15785-1	WL011 - RAW	11/24/2025 12:21 PM	Perfluorooctanoic acid (PFOA)	2806	2.8	ng/L	2.0	EPA 537.1	4	12/03/2025 08:17 PM
15785-1	WL011 - RAW	11/24/2025 12:21 PM	Perfluorononanoic acid (PFNA)	2804	<2.0	ng/L	2.0	EPA 537.1	10	12/03/2025 08:17 PM
15785-1	WL011 - RAW	11/24/2025 12:21 PM	Perfluorodecanoic acid (PFDA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:17 PM
15785-1	WL011 - RAW	11/24/2025 12:21 PM	Perfluoroundecanoic Acid (PFUNA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:17 PM
15785-1	WL011 - RAW	11/24/2025 12:21 PM	Perfluorododecanoic acid (PFDoA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:17 PM
15785-1	WL011 - RAW	11/24/2025 12:21 PM	Perfluorobutanesulfonic acid (PFBS)	2801	2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 08:17 PM
15785-1	WL011 - RAW	11/24/2025 12:21 PM	Perfluorohexanesulfonic acid (PFHxS)	2803	<2.0	ng/L	2.0	EPA 537.1	10	12/03/2025 08:17 PM
15785-1	WL011 - RAW	11/24/2025 12:21 PM	Perfluorooctanesulfonic Acid (PFOS)	2805	3.7	ng/L	2.0	EPA 537.1	4	12/03/2025 08:17 PM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. EPA finalized a National Primary Drinking Water Regulation (NPDWR) establishing legally enforceable levels, called Maximum Contaminant Levels (MCLs), for six PFAS in drinking water. PFOA, PFOS, PFHxS, PFNA, and HFPO-DA as contaminants with

individual MCLs, and PFAS mixtures containing at least two or more of PFHxS, PFNA, HFPO-DA, and PFBS using a Hazard Index MCL to account for the combined and co-occurring levels of these PFAS in drinking water. EPA also finalized health-based, non-enforceable Maximum Contaminant Level Goals (MCLGs) for these PFAS.

3. ng/L is equivalent to parts per trillion
4. Sample received and examined within EPA's recommended holding time.
5. Results in **BOLD** exceed the EPA's MCL.
6. SM - Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.
7. NA - Not Applicable.
8. The following tests were analyzed in other labs: PFAS 537.1 was analyzed by lab MD-209.
9. We certify that the analyses performed for this report are accurate and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.

Reported by,

*T. Davis*

T. Davis, Customer Service Representative

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**
**Reporting Date: 12/08/2025  
PWSID #: MD0060007**

System Name: Town of Mt. Airy  
Sample Address: 000 Ridge Road Mt Airy, MD 21771  
Sample Type: Drinking Water  
Laboratory Certification: #214 Maryland, #134 Maryland, #00107 Virginia  
Received by Lab: Date: 11/24/2025 Time: 04:34 PM  
Sampler: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample ID	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL	Analysis Date/Time
15440-1	WL01 - RAW	11/24/2025 11:37 AM	Perfluorohexanoic Acid (PFHXA)	NA	2.9	ng/L	2.0	EPA 537.1	NA	12/02/2025 03:13 PM
15440-1	WL01 - RAW	11/24/2025 11:37 AM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	2816	<2.0	ng/L	2.0	EPA 537.1	10	12/02/2025 03:13 PM
15440-1	WL01 - RAW	11/24/2025 11:37 AM	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/02/2025 03:13 PM
15440-1	WL01 - RAW	11/24/2025 11:37 AM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/02/2025 03:13 PM
15440-1	WL01 - RAW	11/24/2025 11:37 AM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/02/2025 03:13 PM
15440-1	WL01 - RAW	11/24/2025 11:37 AM	Perfluorotetradecanoic acid (PFTeDA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/02/2025 03:13 PM
15440-1	WL01 - RAW	11/24/2025 11:37 AM	Perfluorotridecanoic acid (PFTrDA)	NA	<2.0	ppt	2.0	EPA 537.1	NA	12/02/2025 03:13 PM
15440-1	WL01 - RAW	11/24/2025 11:37 AM	N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/02/2025 03:13 PM
15440-1	WL01 - RAW	11/24/2025 11:37 AM	N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/02/2025 03:13 PM
15440-1	WL01 - RAW	11/24/2025 11:37 AM	Perfluoroheptanoic acid (PFHpA)	NA	2.0	ng/L	2.0	EPA 537.1	NA	12/02/2025 03:13 PM
15440-1	WL01 - RAW	11/24/2025 11:37 AM	Perfluorooctanoic acid (PFOA)	2806	3.6	ng/L	2.0	EPA 537.1	4	12/02/2025 03:13 PM
15440-1	WL01 - RAW	11/24/2025 11:37 AM	Perfluorononanoic acid (PFNA)	2804	<2.0	ng/L	2.0	EPA 537.1	10	12/02/2025 03:13 PM
15440-1	WL01 - RAW	11/24/2025 11:37 AM	Perfluorodecanoic acid (PFDA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/02/2025 03:13 PM
15440-1	WL01 - RAW	11/24/2025 11:37 AM	Perfluoroundecanoic Acid (PFUNA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/02/2025 03:13 PM
15440-1	WL01 - RAW	11/24/2025 11:37 AM	Perfluorododecanoic acid (PFDoA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/02/2025 03:13 PM
15440-1	WL01 - RAW	11/24/2025 11:37 AM	Perfluorobutanesulfonic acid (PFBS)	2801	5.1	ng/L	2.0	EPA 537.1	NA	12/02/2025 03:13 PM
15440-1	WL01 - RAW	11/24/2025 11:37 AM	Perfluorohexanesulfonic acid (PFHxS)	2803	<2.0	ng/L	2.0	EPA 537.1	10	12/02/2025 03:13 PM
15440-1	WL01 - RAW	11/24/2025 11:37 AM	Perfluorooctanesulfonic Acid (PFOS)	2805	<2.0	ng/L	2.0	EPA 537.1	4	12/02/2025 03:13 PM

**Notes:**

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. EPA finalized a National Primary Drinking Water Regulation (NPDWR) establishing legally enforceable levels, called Maximum Contaminant Levels (MCLs), for six PFAS in drinking water. PFOA, PFOS, PFHxS, PFNA, and HFPO-DA as contaminants with

individual MCLs, and PFAS mixtures containing at least two or more of PFHxS, PFNA, HFPO-DA, and PFBS using a Hazard Index MCL to account for the combined and co-occurring levels of these PFAS in drinking water. EPA also finalized health-based, non-enforceable Maximum Contaminant Level Goals (MCLGs) for these PFAS.

3. ng/L is equivalent to parts per trillion
4. Sample received and examined within EPA's recommended holding time.
5. Results in **BOLD** exceed the EPA's MCL.
6. SM - Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.
7. NA - Not Applicable.
8. The following tests were analyzed in other labs: PFAS 537.1 was analyzed by lab MD-209.
9. We certify that the analyses performed for this report are accurate and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.

Reported by,

*T. Davis*

T. Davis, Customer Service Representative

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**
**Reporting Date: 12/08/2025  
PWSID #: MD0060007**

System Name: Town of Mt. Airy  
Sample Address: 000 Ridge Road Mt Airy, MD 21771  
Sample Type: Drinking Water  
Laboratory Certification: #214 Maryland, #134 Maryland, #00107 Virginia  
Received by Lab: Date: 11/24/2025 Time: 04:34 PM  
Sampler: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample ID	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL	Analysis Date/Time
15684-1	WL03 - RAW	11/24/2025 11:38 AM	Perfluorohexanoic Acid (PFHXA)	NA	3.2	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:56 PM
15684-1	WL03 - RAW	11/24/2025 11:38 AM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	2816	<1.9	ng/L	1.9	EPA 537.1	10	12/03/2025 07:56 PM
15684-1	WL03 - RAW	11/24/2025 11:38 AM	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:56 PM
15684-1	WL03 - RAW	11/24/2025 11:38 AM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:56 PM
15684-1	WL03 - RAW	11/24/2025 11:38 AM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:56 PM
15684-1	WL03 - RAW	11/24/2025 11:38 AM	Perfluorotetradecanoic acid (PFTeDA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:56 PM
15684-1	WL03 - RAW	11/24/2025 11:38 AM	Perfluorotridecanoic acid (PFTrDA)	NA	<1.9	ppt	1.9	EPA 537.1	NA	12/03/2025 07:56 PM
15684-1	WL03 - RAW	11/24/2025 11:38 AM	N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:56 PM
15684-1	WL03 - RAW	11/24/2025 11:38 AM	N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:56 PM
15684-1	WL03 - RAW	11/24/2025 11:38 AM	Perfluoroheptanoic acid (PFHpA)	NA	2.0	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:56 PM
15684-1	WL03 - RAW	11/24/2025 11:38 AM	Perfluorooctanoic acid (PFOA)	2806	3.6	ng/L	1.9	EPA 537.1	4	12/03/2025 07:56 PM
15684-1	WL03 - RAW	11/24/2025 11:38 AM	Perfluorononanoic acid (PFNA)	2804	<1.9	ng/L	1.9	EPA 537.1	10	12/03/2025 07:56 PM
15684-1	WL03 - RAW	11/24/2025 11:38 AM	Perfluorodecanoic acid (PFDA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:56 PM
15684-1	WL03 - RAW	11/24/2025 11:38 AM	Perfluoroundecanoic Acid (PFUNA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:56 PM
15684-1	WL03 - RAW	11/24/2025 11:38 AM	Perfluorododecanoic acid (PFDoA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:56 PM
15684-1	WL03 - RAW	11/24/2025 11:38 AM	Perfluorobutanesulfonic acid (PFBS)	2801	5.2	ng/L	1.9	EPA 537.1	NA	12/03/2025 07:56 PM
15684-1	WL03 - RAW	11/24/2025 11:38 AM	Perfluorohexanesulfonic acid (PFHxS)	2803	<1.9	ng/L	1.9	EPA 537.1	10	12/03/2025 07:56 PM
15684-1	WL03 - RAW	11/24/2025 11:38 AM	Perfluorooctanesulfonic Acid (PFOS)	2805	<1.9	ng/L	1.9	EPA 537.1	4	12/03/2025 07:56 PM

**Notes:**

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. EPA finalized a National Primary Drinking Water Regulation (NPDWR) establishing legally enforceable levels, called Maximum Contaminant Levels (MCLs), for six PFAS in drinking water. PFOA, PFOS, PFHxS, PFNA, and HFPO-DA as contaminants with

individual MCLs, and PFAS mixtures containing at least two or more of PFHxS, PFNA, HFPO-DA, and PFBS using a Hazard Index MCL to account for the combined and co-occurring levels of these PFAS in drinking water. EPA also finalized health-based, non-enforceable Maximum Contaminant Level Goals (MCLGs) for these PFAS.

3. ng/L is equivalent to parts per trillion
4. Sample received and examined within EPA's recommended holding time.
5. Results in **BOLD** exceed the EPA's MCL.
6. SM - Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.
7. NA - Not Applicable.
8. The following tests were analyzed in other labs: PFAS 537.1 was analyzed by lab MD-209.
9. We certify that the analyses performed for this report are accurate and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.

Reported by,

*T. Davis*

T. Davis, Customer Service Representative

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**
**Reporting Date: 12/08/2025  
PWSID #: MD0060007**

System Name: Town of Mt. Airy  
Sample Address: 000 Ridge Road Mt Airy, MD 21771  
Sample Type: Drinking Water  
Laboratory Certification: #214 Maryland, #134 Maryland, #00107 Virginia  
Received by Lab: Date: 11/24/2025 Time: 04:34 PM  
Sampler: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample ID	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL	Analysis Date/Time
15493-1	WL010 - RAW	11/24/2025 11:15 AM	Perfluorohexanoic Acid (PFHXA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:25 PM
15493-1	WL010 - RAW	11/24/2025 11:15 AM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	2816	<2.0	ng/L	2.0	EPA 537.1	10	12/03/2025 07:25 PM
15493-1	WL010 - RAW	11/24/2025 11:15 AM	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:25 PM
15493-1	WL010 - RAW	11/24/2025 11:15 AM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:25 PM
15493-1	WL010 - RAW	11/24/2025 11:15 AM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:25 PM
15493-1	WL010 - RAW	11/24/2025 11:15 AM	Perfluorotetradecanoic acid (PFTeDA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:25 PM
15493-1	WL010 - RAW	11/24/2025 11:15 AM	Perfluorotridecanoic acid (PFTrDA)	NA	<2.0	ppt	2.0	EPA 537.1	NA	12/03/2025 07:25 PM
15493-1	WL010 - RAW	11/24/2025 11:15 AM	N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:25 PM
15493-1	WL010 - RAW	11/24/2025 11:15 AM	N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:25 PM
15493-1	WL010 - RAW	11/24/2025 11:15 AM	Perfluoroheptanoic acid (PFHpA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:25 PM
15493-1	WL010 - RAW	11/24/2025 11:15 AM	Perfluorooctanoic acid (PFOA)	2806	<2.0	ng/L	2.0	EPA 537.1	4	12/03/2025 07:25 PM
15493-1	WL010 - RAW	11/24/2025 11:15 AM	Perfluorononanoic acid (PFNA)	2804	<2.0	ng/L	2.0	EPA 537.1	10	12/03/2025 07:25 PM
15493-1	WL010 - RAW	11/24/2025 11:15 AM	Perfluorodecanoic acid (PFDA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:25 PM
15493-1	WL010 - RAW	11/24/2025 11:15 AM	Perfluoroundecanoic Acid (PFUNA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:25 PM
15493-1	WL010 - RAW	11/24/2025 11:15 AM	Perfluorododecanoic acid (PFDoA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:25 PM
15493-1	WL010 - RAW	11/24/2025 11:15 AM	Perfluorobutanesulfonic acid (PFBS)	2801	2.8	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:25 PM
15493-1	WL010 - RAW	11/24/2025 11:15 AM	Perfluorohexanesulfonic acid (PFHxS)	2803	<2.0	ng/L	2.0	EPA 537.1	10	12/03/2025 07:25 PM
15493-1	WL010 - RAW	11/24/2025 11:15 AM	Perfluorooctanesulfonic Acid (PFOS)	2805	<2.0	ng/L	2.0	EPA 537.1	4	12/03/2025 07:25 PM

**Notes:**

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. EPA finalized a National Primary Drinking Water Regulation (NPDWR) establishing legally enforceable levels, called Maximum Contaminant Levels (MCLs), for six PFAS in drinking water. PFOA, PFOS, PFHxS, PFNA, and HFPO-DA as contaminants with

individual MCLs, and PFAS mixtures containing at least two or more of PFHxS, PFNA, HFPO-DA, and PFBS using a Hazard Index MCL to account for the combined and co-occurring levels of these PFAS in drinking water. EPA also finalized health-based, non-enforceable Maximum Contaminant Level Goals (MCLGs) for these PFAS.

3. ng/L is equivalent to parts per trillion
4. Sample received and examined within EPA's recommended holding time.
5. Results in **BOLD** exceed the EPA's MCL.
6. SM - Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.
7. NA - Not Applicable.
8. The following tests were analyzed in other labs: PFAS 537.1 was analyzed by lab MD-209.
9. We certify that the analyses performed for this report are accurate and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.

Reported by,

*T. Davis*

T. Davis, Customer Service Representative

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**

Reporting Date: 12/08/2025  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Address: 000 Ridge Road Mt Airy, MD 21771  
Sample Type: Drinking Water  
Laboratory Certification: #214 Maryland, #134 Maryland, #00107 Virginia  
Received by Lab: Date: 11/24/2025 Time: 04:34 PM  
Sampler: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample ID	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL	Analysis Date/Time
15665-1	WL04 - RAW	11/24/2025 11:52 AM	Perfluorohexanoic Acid (PFHXA)	NA	5.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:46 PM
15665-1	WL04 - RAW	11/24/2025 11:52 AM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	2816	<2.0	ng/L	2.0	EPA 537.1	10	12/03/2025 07:46 PM
15665-1	WL04 - RAW	11/24/2025 11:52 AM	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:46 PM
15665-1	WL04 - RAW	11/24/2025 11:52 AM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:46 PM
15665-1	WL04 - RAW	11/24/2025 11:52 AM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:46 PM
15665-1	WL04 - RAW	11/24/2025 11:52 AM	Perfluorotetradecanoic acid (PFTeDA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:46 PM
15665-1	WL04 - RAW	11/24/2025 11:52 AM	Perfluorotridecanoic acid (PFTrDA)	NA	<2.0	ppt	2.0	EPA 537.1	NA	12/03/2025 07:46 PM
15665-1	WL04 - RAW	11/24/2025 11:52 AM	N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:46 PM
15665-1	WL04 - RAW	11/24/2025 11:52 AM	N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:46 PM
15665-1	WL04 - RAW	11/24/2025 11:52 AM	Perfluoroheptanoic acid (PFHpA)	NA	2.6	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:46 PM
15665-1	WL04 - RAW	11/24/2025 11:52 AM	Perfluorooctanoic acid (PFOA)	2806	4.0	ng/L	2.0	EPA 537.1	4	12/03/2025 07:46 PM
15665-1	WL04 - RAW	11/24/2025 11:52 AM	Perfluorononanoic acid (PFNA)	2804	<2.0	ng/L	2.0	EPA 537.1	10	12/03/2025 07:46 PM
15665-1	WL04 - RAW	11/24/2025 11:52 AM	Perfluorodecanoic acid (PFDA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:46 PM
15665-1	WL04 - RAW	11/24/2025 11:52 AM	Perfluoroundecanoic Acid (PFUNA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:46 PM
15665-1	WL04 - RAW	11/24/2025 11:52 AM	Perfluorododecanoic acid (PFDoA)	NA	<2.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:46 PM
15665-1	WL04 - RAW	11/24/2025 11:52 AM	Perfluorobutanesulfonic acid (PFBS)	2801	11.0	ng/L	2.0	EPA 537.1	NA	12/03/2025 07:46 PM
15665-1	WL04 - RAW	11/24/2025 11:52 AM	Perfluorohexanesulfonic acid (PFHxS)	2803	<2.0	ng/L	2.0	EPA 537.1	10	12/03/2025 07:46 PM
15665-1	WL04 - RAW	11/24/2025 11:52 AM	Perfluorooctanesulfonic Acid (PFOS)	2805	3.0	ng/L	2.0	EPA 537.1	4	12/03/2025 07:46 PM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. EPA finalized a National Primary Drinking Water Regulation (NPDWR) establishing legally enforceable levels, called Maximum Contaminant Levels (MCLs), for six PFAS in drinking water. PFOA, PFOS, PFHxS, PFNA, and HFPO-DA as contaminants with

individual MCLs, and PFAS mixtures containing at least two or more of PFHxS, PFNA, HFPO-DA, and PFBS using a Hazard Index MCL to account for the combined and co-occurring levels of these PFAS in drinking water. EPA also finalized health-based, non-enforceable Maximum Contaminant Level Goals (MCLGs) for these PFAS.

3. ng/L is equivalent to parts per trillion
4. Sample received and examined within EPA's recommended holding time.
5. Results in **BOLD** exceed the EPA's MCL.
6. SM - Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.
7. NA - Not Applicable.
8. The following tests were analyzed in other labs: PFAS 537.1 was analyzed by lab MD-209.
9. We certify that the analyses performed for this report are accurate and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.

Reported by,

*T. Davis*

T. Davis, Customer Service Representative

**Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771**

Reporting Date: 12/08/2025  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Address: 000 Ridge Road Mt Airy, MD 21771  
Sample Type: Drinking Water  
Laboratory Certification: #214 Maryland, #134 Maryland, #00107 Virginia  
Received by Lab: Date: 11/24/2025 Time: 04:34 PM  
Sampler: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample ID	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL	Analysis Date/Time
15812-1	WL06 - RAW	11/24/2025 11:05 AM	Perfluorohexanoic Acid (PFHXA)	NA	4.3	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:38 PM
15812-1	WL06 - RAW	11/24/2025 11:05 AM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	2816	<1.9	ng/L	1.9	EPA 537.1	10	12/03/2025 08:38 PM
15812-1	WL06 - RAW	11/24/2025 11:05 AM	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:38 PM
15812-1	WL06 - RAW	11/24/2025 11:05 AM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:38 PM
15812-1	WL06 - RAW	11/24/2025 11:05 AM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:38 PM
15812-1	WL06 - RAW	11/24/2025 11:05 AM	Perfluorotetradecanoic acid (PFTeDA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:38 PM
15812-1	WL06 - RAW	11/24/2025 11:05 AM	Perfluorotridecanoic acid (PFTrDA)	NA	<1.9	ppt	1.9	EPA 537.1	NA	12/03/2025 08:38 PM
15812-1	WL06 - RAW	11/24/2025 11:05 AM	N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:38 PM
15812-1	WL06 - RAW	11/24/2025 11:05 AM	N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:38 PM
15812-1	WL06 - RAW	11/24/2025 11:05 AM	Perfluoroheptanoic acid (PFHpA)	NA	2.5	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:38 PM
15812-1	WL06 - RAW	11/24/2025 11:05 AM	Perfluorooctanoic acid (PFOA)	2806	<b>4.3</b>	ng/L	1.9	EPA 537.1	4	12/03/2025 08:38 PM
15812-1	WL06 - RAW	11/24/2025 11:05 AM	Perfluorononanoic acid (PFNA)	2804	<1.9	ng/L	1.9	EPA 537.1	10	12/03/2025 08:38 PM
15812-1	WL06 - RAW	11/24/2025 11:05 AM	Perfluorodecanoic acid (PFDA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:38 PM
15812-1	WL06 - RAW	11/24/2025 11:05 AM	Perfluoroundecanoic Acid (PFUNA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:38 PM
15812-1	WL06 - RAW	11/24/2025 11:05 AM	Perfluorododecanoic acid (PFDoA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:38 PM
15812-1	WL06 - RAW	11/24/2025 11:05 AM	Perfluorobutanesulfonic acid (PFBS)	2801	2.8	ng/L	1.9	EPA 537.1	NA	12/03/2025 08:38 PM
15812-1	WL06 - RAW	11/24/2025 11:05 AM	Perfluorohexanesulfonic acid (PFHxS)	2803	2.4	ng/L	1.9	EPA 537.1	10	12/03/2025 08:38 PM
15812-1	WL06 - RAW	11/24/2025 11:05 AM	Perfluorooctanesulfonic Acid (PFOS)	2805	<b>4.7</b>	ng/L	1.9	EPA 537.1	4	12/03/2025 08:38 PM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. EPA finalized a National Primary Drinking Water Regulation (NPDWR) establishing legally enforceable levels, called Maximum Contaminant Levels (MCLs), for six PFAS in drinking water. PFOA, PFOS, PFHxS, PFNA, and HFPO-DA as contaminants with

individual MCLs, and PFAS mixtures containing at least two or more of PFHxS, PFNA, HFPO-DA, and PFBS using a Hazard Index MCL to account for the combined and co-occurring levels of these PFAS in drinking water. EPA also finalized health-based, non-enforceable Maximum Contaminant Level Goals (MCLGs) for these PFAS.

3. ng/L is equivalent to parts per trillion
4. Sample received and examined within EPA's recommended holding time.
5. Results in **BOLD** exceed the EPA's MCL.
6. SM - Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.
7. NA - Not Applicable.
8. The following tests were analyzed in other labs: PFAS 537.1 was analyzed by lab MD-209.
9. We certify that the analyses performed for this report are accurate and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.

Reported by,

*T. Davis*

T. Davis, Customer Service Representative

Town of Mt. Airy  
PO Box 50  
Mt Airy, MD 21771

Reporting Date: 12/08/2025  
PWSID #: MD0060007

System Name: Town of Mt. Airy  
Sample Address: 000 Ridge Road Mt Airy, MD 21771  
Sample Type: Drinking Water  
Laboratory Certification: #214 Maryland, #134 Maryland, #00107 Virginia  
Received by Lab: Date: 11/24/2025 Time: 04:34 PM  
Sampler: K. Ramsey, 2084KR, WTL of MD

### Analytical Results

Sample ID	Sample Source	Date/Time Collected	Parameter	Parameter Code	Results	Units	Reporting Limit	Method	MCL	Analysis Date/Time
15401-1	WL07 - RAW	11/24/2025 12:15 PM	Perfluorohexanoic Acid (PFHXA)	NA	21.0	ng/L	1.9	EPA 537.1	NA	12/02/2025 12:36 PM
15401-1	WL07 - RAW	11/24/2025 12:15 PM	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	2816	<1.9	ng/L	1.9	EPA 537.1	10	12/02/2025 12:36 PM
15401-1	WL07 - RAW	11/24/2025 12:15 PM	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/02/2025 12:36 PM
15401-1	WL07 - RAW	11/24/2025 12:15 PM	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/02/2025 12:36 PM
15401-1	WL07 - RAW	11/24/2025 12:15 PM	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/02/2025 12:36 PM
15401-1	WL07 - RAW	11/24/2025 12:15 PM	Perfluorotetradecanoic acid (PFTeDA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/02/2025 12:36 PM
15401-1	WL07 - RAW	11/24/2025 12:15 PM	Perfluorotridecanoic acid (PFTrDA)	NA	<1.9	ppt	1.9	EPA 537.1	NA	12/02/2025 12:36 PM
15401-1	WL07 - RAW	11/24/2025 12:15 PM	N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/02/2025 12:36 PM
15401-1	WL07 - RAW	11/24/2025 12:15 PM	N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/02/2025 12:36 PM
15401-1	WL07 - RAW	11/24/2025 12:15 PM	Perfluoroheptanoic acid (PFHpA)	NA	7.5	ng/L	1.9	EPA 537.1	NA	12/02/2025 12:36 PM
15401-1	WL07 - RAW	11/24/2025 12:15 PM	Perfluorooctanoic acid (PFOA)	2806	<b>14.0</b>	ng/L	1.9	EPA 537.1	4	12/02/2025 12:36 PM
15401-1	WL07 - RAW	11/24/2025 12:15 PM	Perfluorononanoic acid (PFNA)	2804	1.9	ng/L	1.9	EPA 537.1	10	12/02/2025 12:36 PM
15401-1	WL07 - RAW	11/24/2025 12:15 PM	Perfluorodecanoic acid (PFDA)	NA	2.6	ng/L	1.9	EPA 537.1	NA	12/02/2025 12:36 PM
15401-1	WL07 - RAW	11/24/2025 12:15 PM	Perfluoroundecanoic Acid (PFUNA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/02/2025 12:36 PM
15401-1	WL07 - RAW	11/24/2025 12:15 PM	Perfluorododecanoic acid (PFDoA)	NA	<1.9	ng/L	1.9	EPA 537.1	NA	12/02/2025 12:36 PM
15401-1	WL07 - RAW	11/24/2025 12:15 PM	Perfluorobutanesulfonic acid (PFBS)	2801	2.8	ng/L	1.9	EPA 537.1	NA	12/02/2025 12:36 PM
15401-1	WL07 - RAW	11/24/2025 12:15 PM	Perfluorohexanesulfonic acid (PFHxS)	2803	<1.9	ng/L	1.9	EPA 537.1	10	12/02/2025 12:36 PM
15401-1	WL07 - RAW	11/24/2025 12:15 PM	Perfluorooctanesulfonic Acid (PFOS)	2805	3.7	ng/L	1.9	EPA 537.1	4	12/02/2025 12:36 PM

Notes:

1. MCL is EPA's maximum contaminant level under primary drinking water regulations.
2. EPA finalized a National Primary Drinking Water Regulation (NPDWR) establishing legally enforceable levels, called Maximum Contaminant Levels (MCLs), for six PFAS in drinking water. PFOA, PFOS, PFHxS, PFNA, and HFPO-DA as contaminants with

individual MCLs, and PFAS mixtures containing at least two or more of PFHxS, PFNA, HFPO-DA, and PFBS using a Hazard Index MCL to account for the combined and co-occurring levels of these PFAS in drinking water. EPA also finalized health-based, non-enforceable Maximum Contaminant Level Goals (MCLGs) for these PFAS.

3. ng/L is equivalent to parts per trillion
4. Sample received and examined within EPA's recommended holding time.
5. Results in **BOLD** exceed the EPA's MCL.
6. SM - Greenberg, Clesceri and Eaton, Standard Methods for the Examination of Water and Wastewater.
7. NA - Not Applicable.
8. The following tests were analyzed in other labs: PFAS 537.1 was analyzed by lab MD-209.
9. We certify that the analyses performed for this report are accurate and that the laboratory tests were conducted by methods approved by the US Environmental Protection Agency and the Maryland Department of the Environment.

Reported by,

*T. Davis*

T. Davis, Customer Service Representative