



NOTES:

1. USE 13mm 1/2" GRADE 60 STEEL REINFORCEMENT
2. TO BE INSTALLED PER MANUFACTURER'S WRITTEN INSTRUCTIONS
3. THE CENTER WIDTH SIZE MAY VARY FROM 10"-14"

COPOLYMER POLYPROPYLENE PLASTIC
MANHOLE STEP

NTS



The Town of Mount Airy, Maryland

[Signature]
APPROVED

COPOLYMER
POLYPROPYLENE
PLASTIC
MANHOLE STEP

By:
MDH

Date

7/21/10

Standard Detail No.

S-09