


NOTES:

1. ALL WATER MAINS AND LATERALS SHALL HAVE A MINIMUM COVER OF 4'-0".
2. SEE STANDARD DETAIL S-18 FOR TRENCH WIDTH PER PIPE SIZES.
3. SEE STANDARD DETAIL S-19 AND S-20 FOR PIPE INSTALLATION.

PIPE AND TRENCH DETAIL  
NTS

	The Town of Mount Airy, Maryland  APPROVED	PIPE AND TRENCH DETAIL	By: MDH	Date: 7/21/16
				Standard Detail No. W-01