



STRAP PIPES WHEN USING FITTINGS ON ANGLE WHERE CONCRETE BUTTRESS CANNOT BE USED EFFECTIVELY.

NOTES:

1. A CLASS B CONCRETE BUTTRESS MUST BE ALONG WITH THE USE OF APPROVED MECHANICAL JOINT RESTRAINTS AT ALL JOINTS
2. THE BLUE RAISED PAVEMENT MARKER IS TO BE 5' FROM THE CENTER LINE OF THE ROAD.

FIRE HYDRANT SETTINGS

NTS



The Town of Mount Airy, Maryland

Bleim

APPROVED

FIRE HYDRANT SETTINGS

By: MDH

Date

8-8-11

Standard Detail No.

W-02