


NOTES:

1. COPPER PIPE FOR WATER SERVICES SHALL BE SEAMLESS COPPER SERVICE PIPE SUITABLE FOR USE AS UNDERGROUND SERVICE CONNECTIONS AND GENERAL PLUMBING IN ACCORDANCE WITH ASTM B68-56, CLASS "K" SPECIFICATIONS, U.S. GOVERNMENT TYPE "K" SPECIFICATIONS WW-T-799
2. NO CURB INSTALLATIONS IN SIDEWALK
3. ALLOWANCE FOR HIGH-DENSITY POLYETHYLENE (H.D.P.E.) PIPE FOR WATER HOUSE CONNECTION (RESIDENTIAL, COMMERCIAL, OR INDUSTRIAL) MAY BE PERMITTED FROM THE CURB STOP TO THE BUILDING/HOUSE. ALL H.D.P.E SHALL BE COPPER TUBE SIZE (C.T.S.) MEETING ASTM D2737 STANDARD ONLY. POLYETHYLENE PIPE MEETING ASTM D2239 STANDARD FOR IRON PIPE SIZE (I.P.S.) OR "WELL PIPE" WILL NOT BE ACCEPTED.
4. COMMERCIAL BUILDINGS: WATER METERS SHALL BE INSTALLED IN A ROOM WHERE W.H.C. ENTERS HOUSE/BUILDING. WHERE MULTIPLE METERS ARE INSTALLED WITHIN SAME BUILDING ALL METERS MUST BE LOCATED IN SAME ROOM WHERE W.H.C. ENTERS BUILDING. THIS ROOM SHALL BE ACCESSIBLE TO TOWN'S WATER MAINTENANCE EMPLOYEES FOR PERIODIC AND EMERGENCY MAINTENANCE.
5. 18" ABOVE WATER LINE USE TAPE. IF H.D.P.E. PIPE USE METALLIC TAPE OTHERWISE USE BLUE PLASTIC TAPE OVER COPPER.

## HOUSE SERVICE CONNECTION

NTS

	The Town of Mount Airy, Maryland <div style="text-align: center;">             _____            APPROVED         </div>	HOUSE SERVICE CONNECTION	By: MDH	Date 7/21/10
				Standard Detail No. W-03