



NOTES:

1. NO VALVE BOXES IN SIDEWALK.
2. COMMERCIAL BUILDINGS: WATER METERS SHALL BE INSTALLED IN A ROOM WHERE W.H.C. ENTERS HOUSE/BUILDING. WHERE MULTIPLE METERS ARE INSTALLED WITHIN SAME BUILDING ALL METERS MUST BE LOCATED IN SAME ROOM WHERE W.H.C. ENTERS BUILDING. THIS ROOM SHALL BE ACCESSIBLE TO TOWN'S WATER MAINTENANCE EMPLOYEES FOR PERIODIC AND EMERGENCY MAINTENANCE.
3. 18" ABOVE WATER LINE USE TAPE.

**COMMERCIAL/INDUSTRIAL WATER  
SERVICE CONNECTION**

NTS



The Town of Mount Airy, Maryland

*[Signature]*  
APPROVED

COMMERCIAL/INDUSTRIAL  
WATER SERVICE  
CONNECTION

By:  
MDH

Date  
7/21/10

Standard Detail  
No.

W-06