


NOTES:

1. COMMERCIAL BUILDINGS: WATER METERS SHALL BE INSTALLED IN A ROOM WHERE W.H.C. ENTERS HOUSE/BUILDING. WHERE MULTIPLE METERS ARE INSTALLED WITHIN SAME BUILDING ALL METERS MUST BE LOCATED IN SAME ROOM WHERE W.H.C. ENTERS BUILDING. THIS ROOM SHALL BE ACCESSIBLE TO TOWN'S WATER MAINTENANCE EMPLOYEES FOR PERIODIC AND EMERGENCY MAINTENANCE.
2. 18" ABOVE WATER LINE USE TAPE.
3. ALL CONNECTION CAPS SHALL BE INSTALLED WITH SINGLE PIPE ONLY AND WITH MECHANICALLY RESTRAINED JOINTS FROM WATER MAIN TO CAP. WHERE LONGER LENGTH OF PIPE IS REQUIRED TO EXTEND OUTSIDE OF ROAD RIGHT OF WAY OR AS APPROVED BY THE TOWN, THEN MECHANICAL RESTRAINTS OR FIELD LOCK GASKETS SHALL BE REQUIRED AT EVERY JOINT BETWEEN THE WATER MAIN AND CAP.

WATER SERVICE CONNECTION CAP

NTS

	The Town of Mount Airy, Maryland  <hr style="width: 100%;"/>	WATER SERVICE CONNECTION CAP	By: MDH	Date 8/8/11
	APPROVED			